

ANSWER TO PLUMBING COMMENTS 08-25-22

INDICATE COMPLIANCE WITH NFPA 58 § 6.4.4.3, PROVIDE ON PLAN DISTANCE OF PROPOSED TANK TO SOURCES OF IGNITION AND INTAKES. CONTAINERS FILLED ON SITE MUST BE LOCATED SO THAT THE FILLING CONNECTION AND FIXED MAX. LIQUID LEVEL GAUGE ARE AT LEAST 10 FT FROM ANY EXTERIOR SOURCE OF IGNITION (E.G., OPEN FLAME, WINDOW AC, COMPRESSOR), INTAKE TO DIRECT-VENTED GAS APPLIANCE, OR INTAKE TO A MECHANICAL VENTILATION SYSTEM.

Answer: Refer to revised sheet P-1