


Date: 08.21.2023

Project Address: 7725 SW 114th St, Miami, FL 33156

Permit Number: BL2023-0660



Landscape Review

7. Update signed and sealed Certificate of Landscape compliance by adding permit number BL2023-0660

[Noted and revised.](#)

8. Landscape plans must have all setbacks, FFE, width of driveway at property line and street edge and all interior side setbacks walkway/dwy to property line etc.

[See landscape plans. All information has been depicted in plan L-200.](#)

9. 5 trees required in the right of way add additional tree

[Noted. 5 total trees have been added to R.O.W](#)

11. Separate tree/ palm removal/relocation permit required with plans to be submitted, review, and approved before master permit can have a complete review of the landscape plan in the master

[Noted](#)

12. Shrubs used to screen mechanical equipment must be a minimum of 36 inches label all mechanical equipment and note all screening.

[All shrubs used for screening mechanical equipment will be planted at a minimum of 36" Ht. see landscape list and notes in plan L-200](#)

13. Sheet L.2100 must have a landscape legend of all remaining trees keeping the same tree numbers as the survey and list in table the tree number, name of tree, height, diameter, and canopy.

[List of existing trees to remain on site has been added to sheet L-200](#)

17. Put irrigation sheet with the plumbing sheets so the plumbing inspector can review and if any landscape lighting put this as an e- sheet so the electrical inspector can review these sheets

[Noted, irrigation plan has been revised](#)