

A		LIGHT FIXTURE DESIGNATION, FLOODLIGHT, SEE LIGHTING FIXTURE	
		LIGHT FIXTURE DESIGNATION, SEE LIGHTING FIXTURE SCHEDULE	
		LIGHTING FIXTURE, SURFACE MOUNTED	
		LIGHTING FIXTURE, RECESSED MOUNTED	
		LIGHTING FIXTURE, WALL MOUNTED	
		1 X 4 FLUORESCENT LIGHT FIXTURE	
		TOGGLE SWITCH 120/277V, 20 AMP., (M.H. = 48° A.F.F.), 3-WAY	
		TOGGLE SWITCH 120/277V, 20 AMP., (M.H. = 48° A.F.F.), 4-WAY	
		TOGGLE SWITCH 120/277V, 20 AMP., (M.H. = 48° A.F.F.)	
		TOGGLE SWITCH 120/277V, 20 AMP., KEYMOUNT (M.H. = 48° A.F.F.)	
		FAN SWITCH 120/277V, 20 AMP., (HOSERPOWER RATED) (M.H. = 48° A.F.F.)	
		DOOR JAMB SWITCH (DOOR ACTIVATED) 120/277V, 20 AMP., (M.H. = 48° A.F.F.)	
		FAN AND LIGHTING SWITCH 120/277V, 20 AMP., WITH (M.H. = 48° A.F.F.), 3-WAY	
		TOGGLE SWITCH 120/277V, 20 AMP., WITH PILOT LIGHT (M.H. = 48° A.F.F.)	
		TOGGLE SWITCH 120/277V, 20 AMP., EXPLOSION-PROOF	
		SPEED SWITCH 120/277V, 20 AMP. U.O.N. (M.H. = 48° A.F.F.)	
		SINGLE PHASE MANUAL MOTOR, MOTOR (M.H. = 48° A.F.F.)	
		DIMMER SWITCH 120/277V, 20 AMP., (M.H. = 48° A.F.F.)	
		DUPLEX RECEPTACLE, 20 AMP., 125V., (M.H. = 18° A.F.F.)	
		DUPLEX RECEPTACLE, 20 AMP., 125V., RECESS FLOOR MOUNTED	
		DUPLEX RECEPTACLE, 20 AMP., 125V., CEILING MOUNTING.	
		USB OUTLET, (M.H. = 18° A.F.F.)	
		DUPLEX RECEPTACLE, 20 AMP., 125V., TOP HALF SWITCHED, M.H. = 18° A.F.F., UNLESS OTHERWISE NOTED	
		DUPLEX RECEPTACLE, 20 AMP., 125V., ISOLATED GROUND AND SURGE PROTECTED, (M.H. = 18° A.F.F.)	
		SINGLE RECEPTACLE, 20 AMP., 125V., COORDINATED M.H. WITH DESIGNATED EQUIPMENT	
		FOUR-POLE OUTLET RECEPTACLE, 20A, 125V., (M.H. = 18° A.F.F.)	
		SPECIAL PURPOSE OUTLET 220V ¾" RANGE OUTLET, COORD. W/ EQUIPT.	
		DUPLEX RECEPTACLE, 20 AMP., 125V., MOUNT ABOVE COUNTER	
		30 AMP., 125V., TWIST LOCK RECEPTACLE FOR FLOOR POLISHING MACHINE	
		JUNCTION BOX, MOUNTING AS SHOWN	
		CARAGE DOOR PUSH BUTTON SWITCH	
		ELECTRIC MOTOR	
		MOTOR STARTER	
		COMBINATION MOTOR STARTER, TYPE AS DESIGNATED	
		ELECTRICAL PANEL, SEE PANEL SCHEDULE SHEET(S) FOR DETAILS	
		EXISTING EQUIPMENT TO REMAIN	
		NEW EQUIPMENT OR WORK OF THIS PROJECT	
		SMOKE ALARM/CO SENSOR COMBINATION 120V WITH BATTERY BACK UP	
		CIRCUIT BREAKER, TYPE AND SIZE AS PER DRAWINGS.	
		LOW VOLTAGE LIGHTING KEYPAD	
		CLOCK	
		BELL	
		TELEPHONE PORT FLOOR MOUNTED	
		DUAL TELEPHONE OUTLET MOUNTED AT 18" A.F.F. USE CAT-5 W/1" STUB UP 6" ABOVE CEILING.	
		DUAL TELEPHONE OUTLET MOUNTED AT 54" A.F.F. USE CAT-5 W/1" STUB UP 6" ABOVE CEILING.	
		COMPUTER/DATA/TELEPHONE OUTLET MOUNTED AT 18" A.F.F. USE CAT-5 W/1" STUB UP 6" ABOVE CEILING.	
		TELEVISION OUTLET (M.H. = 18° A.F.F.)	
		LIGHTING TRANSFORMER	
ABBREVIATIONS			
A.C.	ABOVE COUNTER	G.F.I.	GROUND FAULT INTERRUPTER
A.F.	ARC FAULT	G.F./M.R.	GROUND FAULT INTERRUPTER WITH WEATHER RESISTANT WIRLE IN USE TYPE COVER
A.F.F.	ABOVE FINISHED FLOOR		
A.S.W.	ABOVE SHADOW ROFT.		
B.C.	BELOW FINISHED CEILING	L.C.	LOOKALIKE COUNTER MOUNTING HEIGHT
B.F.G.	BELOW FINISHED GRADE	M.H.	MAIN ELECTRICAL RENEW
C.B.	CIRCUIT BREAKER	M.E.R.	NEW DEVICE
C.L.	DEDICATED FOR COMPUTER, PROVIDE DEDICATED GROUND AND NEUTRAL	N.F.	NOT FUSED
D	DEDICATED FOR COMPUTER, PROVIDE DEDICATED GROUND AND NEUTRAL	NL	NIGHT LIGHT
EM	PROVIDE EMERGENCY BATTERY BACK W/EQUIRE, CONNECT AHEAD OF ALL SWITCHES.	T.C.	REMOVING CABINET TIME SWITCH
FLR	FLOOR	U.O.N.	UNLESS OTHERWISE NOTED
E	EXISTING DEVICE TO REMAIN	WR.	WEATHER PROOF WEATHER RESISTANT
RL	EXISTING RELOCATED	TX	TRANSFORMER
		M.S.	MOTION SENSOR
		ATS.	AUTOMATIC TRANSFER SWITCH
		C.L.G.	CEILING
		RM	EXISTING TO BE REMOVED

[illegible]