

Shirley Borg

To: Pinecrest
Subject: FW: casa OHAD BL2023-1640

From: Felipe Alvarado <felipe@faoarchitecture.com>
Subject: Re: casa OHAD

.

We revised the batt insulation to spray foam insulation as revised on plans.
The foam insulation only happens in areas where shown in plans.
The rigid insulation is used almost in the entirety of the the roof. It will be used to insulate and to provide slope for drainage as well. So yes note #71 does apply.

Regards,

Felipe Alvarado
R.A. LEED AP
FAO Architecture

<A-302.pdf>