



VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156



Allen
Slamic

Digitally signed by Allen
Slamic
DN: cn=Allen Slamic,
o=AlexAllen Studio
Architects PLLC, ou,
email=allen@alexallenst
udio.com, c=US
Date: 2024.01.17
08:42:50 -05'00'

PERMIT # **BL-2022-0447**

JOB ADDRESS **12020 SW 77th Avenue, Pinecrest, FL 33156**

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
E1	A	24" X 36"	CSMT	FL20-1234	57.0	42.6	60.0	60.0
E2	N/A	4" X 2" X 96"	MULLION	20-1234.5	—	—	—	—
A1	A	144"H X 360"W	SLIDING	FL #27938	52.03	39.95	70	63
A2	A	144"H X 360"H	SLIDING	FL #27938	45.29	41.80	70	63
N	A	144"H X 158"H	SLIDING	FL #27938	52.03	39.95	70	63
E	A	137"H X 45"W	FIXED	FL #40967	52.03	39.95	50	50
B	A	137"H X 120"W	FIXED	FL #40967	43.44	39.95	50	50
M	A	137"H X 36"W	FIXED	FL #40967	52.03	39.95	50	50
K	B	84"H X 30"W	FIXED CSMT	FL #29872	45.29	41.80	70	70
C	B	84"H X 45"W	CSMT	FL #29872	45.29	41.80	70	70
H	A	137"H X 60"W	FIXED	FL #40967	52.03	39.95	50	50
G	A	137"H X 180"W	FIXED	FL #40967	43.44	39.95	50	50
F	A	120"H X 120"W	SLIDING	FL #27938	43.44	39.95	70	63
O	A	104"H X 60"W	FIXED	FL #40967	43.44	39.95	50	50
D	A	104"H X 120"W	FIXED	FL #40967	52.03	39.95	50	50
I	A	104"H X 300"W	FIXED	FL #40967	43.44	39.95	50	50
L	B	84"H X 90"W	FIXED CSMT/CSMT	FL #29872	55.75	41.80	70	70
J	B	84"H X 45"W	FIXED CSMT	FL #29872	45.29	41.80	70	70

- 1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.
- 2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)