



TABLE 4-2 CHANNEL SELECTION

IF TOTAL EXTENSION IS NOT GREAT THAN:	MAXIMUN CHANNEL GAUGE	MINIMUM CHANNEL PROFILE
6"	24	3" X 1.5"
18"	22	3" X 2"
30"	18	3" X 2"

USE OF 2" WIDE HANGERS		IN 1.5	2	3	6	16	18	24	28	30	48	80
22 GAUGE, 2" X 1.5" HANGERS MAY BE SUBSTITUTED FOR 3" HANGERS FOR DUCTS WITH WIDTHS NOT OVER 48" AND DEPTHS NOT OVER 24" PROVIDED THAT ONE JOINT OCCURS BETWEEN HANGERS AND THE MAXIMUM HANGER SPACING IS 4 FT. EXCEPTION: WHEN DUCT PERIMETER IS 80" OR LESS AND DOES NOT REQUIRE REINFORCEMENT TWO PERMITTED BETWEEN HANGERS.		MM 38	51	76	152	.41 M	.46 M	.61 M	.71 M	.76 M	1.22 M	2.03 M
		FT	4	6	8	18 GA	22 GA	24 GA				
		M	38	51	76	152	.7534	.6010				



AHU CLOSET INSTALLATION


NTS



N.T.S.




NTS



(SMACNA 2.16)

N.T.S

12721 SW 30th ST. MIAMI, FL 33175
PH: (305) 505-6910
email: julio@novusarchetype.com
AA26001460
Qualifier: Julio Pulido, AIA
License #: AR93904
Qualifier : Salvador Ben Mitran, NCAR
License #: AR99606



Rolando Maqueira, PE
PE #55482

7220 SW 39th Terrace Tel: 305.669.5595
Miami, Florida 33155 cad@maqueira.com

Rolando
Maqueira

Digitally signed by Rolando Maqueira
DN: c=US, o=MAQUEIRA
ENGINEERING CONSULTANTS,
dnQualifier=A01410D00000178F0A29
85F000F43D5, cn=Rolando Maqueira
Date: 2023.04.18 14:30:56 -04'00'

Eva Vaccaro

2-Story Addition

12940 SW 63 Ave Pinecrest FL
33156

Project number	22-01
Date	04-16-202
Drawn by	N.
Checked by	R.
SHEET TITLE	

Proposed House 2nd Level Floor Plan

SHEET No.

M210