

A		LIGHT FIXTURE DESIGNATION, FLOODLIGHT, SEE LIGHTING FIXTURE LIGHTING FIXTURE DESIGNATION, SEE LIGHTING FIXTURE SCHEDULE
		LIGHTING FIXTURE, SURFACE MOUNTED
		LIGHTING FIXTURE, RECESS MOUNTED
		LIGHTING FIXTURE, WALL MOUNTED
		1 X 4 FLUORESCENT LIGHT FIXTURE
\$		TOGGLE SWITCH 120/277V, 20 AMP. (M.H. = 48° AFF.) , 3-WAY
\$		TOGGLE SWITCH 120/277V, 20 AMP. (M.H. = 48° AFF.) , 1-WAY
\$		TOGGLE SWITCH 120/277V, 20 AMP. (M.H. = 48° AFF.)
\$		TOGGLE SWITCH 120/277V, 20 AMP. KEYSWITCH (M.H. = 48° AFF.)
\$		DOOR SWITCH 120/277V, 20 AMP. (HORSEREPARE RATED) (M.H. = 48° AFF.)
\$		FAN/JAM SWITCH (DOOR ACTIVATED) 120/277V, 20 AMP. (M.H. = 48° AFF.)
\$		TOGGLE SWITCH 120/277V, 20 AMP. WITH (M.H. = 48° AFF.)
\$		10 MIN. TIME DELAY, RELAY BY MECH. CONT. INSTALLED BY E.C.
\$		FAN AND LIGHTING SWITCH 120/277V, 20 AMP. (M.H. = 48° AFF.) , 3-WAY
\$		TOGGLE SWITCH 120/277V, 20 AMP. WITH PILOT LIGHT (M.H. = 48° AFF.)
\$		TOGGLE SWITCH 120/277V, 20 AMP. EXPLOSION-PROOF
\$		SPEED SWITCH 120/277V, 20 AMP. U.O.N. (M.H. = 48° AFF.)
\$		SINGLE PHASE MANUAL MOTOR STARTER, (M.H. = 48° AFF.)
\$		DIMMER SWITCH, 20 AMP. (M.H. = 48° AFF.)
\$		DIMMER SWITCH, 20 AMP., 125V, (M.H. = 18° AFF.)
\$		DUPLEX RECEPTACLE, 20 AMP., 125V, RECESS FLOOR MOUNTING
\$		DUPLEX RECEPTACLE, 20 AMP., 125V, CEILING MOUNTING
\$		USB OUTLET, (M.H. = 18° AFF.)
\$		DUPLEX RECEPTACLE, 20 AMP., 125V, TOP HALF SWITCHED, (M.H. = 18° AFF., UNLESS OTHERWISE NOTED)
\$		DUPLEX RECEPTACLE, 20 AMP., 125V, ISOLATED, OPEN AND SHORE PROTECTED, (M.H. = 18° AFF.)
\$		SINGLE RECEPTACLE, 20 AMP., 125V, COORDINATE M.H. WITH DEDICATED EQUIPMENT
\$		FOUR-FLUX DOW RECEPTACLE, 20A, 125V, (M.H. = 18° AFF.)
\$		SPECIAL PURPOSE OUTLET 220V E.C. RANGE OUTLET, COORD. W/ EQUIPT.
\$		DUPLEX RECEPTACLE, 20 AMP., 125V, RECESS FLOOR MOUNTING
\$		30 AMP., 125V, TWIST LOCK RECEPTACLE FOR FLOOR POLISHING MACHINE BOX MOUNTING AS SHOWN
\$		GARAGE DOOR PUSH BUTTON SWITCH
\$		ELECTRIC MOTOR
\$		MOTOR STARTER
\$		COMBINATION MOTOR STARTER, TYPE AS DESIGNATED
\$		ELECTRIC PANEL, SEE PANEL SCHEDULE SHEET(S) FOR DETAILS
\$		EXISTING EQUIPMENT TO REMAIN
\$		NEW EQUIPMENT OR WORK OF THIS PROJECT
\$		SMOKE ALARM/CO SENSOR CONNECTION 120V WITH BATTERY BACK UP
\$		CIRCUIT BREAKER, TYPE AND SIZE AS PER DRAWINGS.
\$		LOW VOLTAGE LIGHTING KEYPAD
\$		CLOCK
\$		BELL
\$		TELEPHONE FLOOR MOUNTED
\$		DUAL TELEPHONE OUTLET MOUNTED AT 18° AFF. USE CAT-5 W/4" STUB UP 6" ABOVE CEILING.
\$		DUAL TELEPHONE OUTLET MOUNTED AT 54° AFF. USE CAT-5 W/4" STUB UP 6" ABOVE CEILING.
\$		COMPUTER/TELEPHONE OUTLET MOUNTED AT 18° AFF. USE CAT-5 W/4" STUB UP 6" ABOVE CEILING.
\$		TELEVISION OUTLET (M.H. = 18° AFF.)
\$		LIGHTING TRANSFORMER

		ABBREVIATIONS			
A.C.		AC POWER	G.F.I.		GROUND FAULT INTERRUPTER
A.F.F.		APARTMENT	G.F.I. NR		GROUND FAULT INTERRUPTER WITH NEUTRAL RECEPTOR WHILE IN USE TYPE COVER
A.S.W.		ABOVE FINISHED FLOOR			
B.F.C.		BELOW WINDOW ROFT.			
		BELOW FINISHED CEILING			
B.F.G.		BELOW FINISHED GRADE	M.H.	L.C.	LOOKABLE COVER
C.B.		CIRCUIT BREAKER			MOVING HEIGHT
C.L.		CENTER LINE	N	M.E.R.	MAIN ELECTRICAL ROOM
D		DEDICATED FOR COMPUTER, PERIODICALLY DEDICATED	N.F.		NEW FUSE
		GROUND AND NEUTRAL	NL		NIGHT LIGHT
		PROVIDE EMERGENCY	T.C.		TERMINAL CABINET
EM		BATTERY PACK W/UTLITY, CONNECT AHEAD OF ALL SWITCHES.	T.S.		TIME SWITCH
			U.O.N.		UNLESS OTHERWISE NOTED
			WR.	WP.	WEATHER PROOF WEATHER RESISTANT
FLR.		FLOOR	TX		TRANSFORMER
E		EXISTING DEVICE TO REMAIN	M.S.		MOTION SENSOR
RL		EXISTING RELOCATED	Q.C.	ATS.	AUTOMATIC TRANSFER SWITCH
			CLM		CEILING
					EXISTING TO BE REMOVED

[illegible]