

July 24, 2024

Village of Pinecrest
12645 Pinecrest Pkwy, Pinecrest, FL 33156

Re: 6545 SW 131th Street
Pinecrest, Florida 33156
Permit #BL2024-0887
Attn: Plan Reviewer

Dear Sir or Madam,

Please find building comments below under REV1:


Plumbing

1. Indicate compliance with NFPA 58 § 6.4.4.3, provide on plan distance of proposed tank to sources of ignition and intakes. Containers filled on site must be located so that the filling connection and fixed max. liquid level gauge are at least 10 ft from any exterior source of ignition (e.g., open flame, window ac, compressor), intake to direct-vented gas appliance, or intake to a mechanical ventilation system.

R: Please refer to Updated Sheet PS-100. Dimensions and compliance note shown.

If you should have further questions, please contact us at your earliest convenience.

Sincerely,



Date:
2024.07.24
14:55:07 -04'00'

Amarilis Rodriguez, P.E
ARPE Engineering, Inc.

V:\24-0307 CASA ROBLES AT 6545 SW 131 ST - PINECREST (FAO ARCH)\12.DOCs\RTC-07-22-2024 REV1.doc