

November 18, 2024

Village of Pinecrest
12645 Pinecrest Pkwy, Pinecrest, FL 33156

Re: 6545 SW 131th Street
Pinecrest, Florida 33156
Permit #BL2024-0887
Attn: Plan Reviewer

Dear Sir or Madam,

Please find building comments below under REV2:

4. Auxiliary Power Supply: New residential and commercial structures and substantial Improvements to residential structures exceeding 50 percent of the market value of the existing structure shall include one of the following improvements necessary to provide auxiliary power during electrical power outages:


- a) permanent Installation of a stand by generator (separate permit) or
- b) installation of a power inlet and either a separate electric or interlock allowing for connection to a portable generator or
- c) Solar panel and battery pack necessary to provide auxiliary power

Please note that this is separate from Solar Ready requirement and must be in place prior to receiving TCO or CO.

R: Please Refer to the Modified Note on Riser Diagram Clarifying Camlock Connection to be used for a Portable Generator Tie-in. Additionally, Please Refer to Cut Sheet.

If you should have further questions, please contact us at your earliest convenience.

Sincerely,



Date:
2024.11.18

Amabilis Rodriguez, P.E.

ARPE Engineering, Inc.

V:\24-0307 CASA ROBLES AT 6545 SW 131 ST - PINECREST (FAO ARCH)\12.DOCs\RTC-11-18-2024 REV2.doc