

Responses to Review Comments

Location: 6100 W Suburban Dr
Pinecrest, FL 33156

Date: August 27, 2024

Applicant:
Process No.: BL2024-1024

Municipality: Pinecrest

Section: Building
Reviewer: Paul Buckler

Responses By: Nelson de León, AIA

The following are written responses to the attached review comments from the Building Department dated 08/01/24:

Remarks: 1) A-01.0: Identify all site features and cross-reference to applicable details or note as by separate permit, ex., pool deck. Delineate the water service line from meter to residence.

Response: Site details and notes added, see Sheet A-01.0, A-02.0 & A-02.1 Rev 1. Water service delineated from meter to residence, see Sheet A-01.0 Rev 1.

Remarks: 2) Provide accessible full bath @ main floor (2/8) on compliant route.

Response: Accessible full bath provided at first floor, see Sheet A-02.0 & A-02.3 Rev 1.

Respectfully submitted,

Nelson de León, AIA
Locus Architecture Inc.