CODE ANALYSIS

SCOPE OF WORK
THIS PROJECT INVOLVES THE DESIGN AND CONSTRUCTION OF A NEW SINGLE-STORY BUILDING TO BE LOCATED WITHIN GARY MATZNER PARK. THE BUILDING WILL INCLUDE RESTROOMS, AN ADJACENT TICKET WINDOW OFFICE ON ONE SIDE, AND A STORAGE SPACE FOR MAINTENANCE ON THE OTHER SIDE, CLASSIFIED AS S-1 USE. THE PRIMARY OBJECTIVE IS TO PROVIDE FUNCTIONAL, ACCESSIBLE, AND DURABLE FACILITIES TO ENHANCE THE PARK'S INFRASTRUCTURE AND OPERATIONS.

ABBREVIATIONS	
N/A	NOT APPLICABLE AS PART OF THIS PROJECT
AGP	ABOVE GRADE PLAN - STORY
FDVA	FIRE DEPARTMENT VEHICLE ACCESS
FSD	FIRE SEPARATION DISTANCE
AHJ	AUTHORITY HAVING JURISDICTION
OL	OCCUPANT LOAD

APPLICABLE CODES		
2023	(A)	FLORIDA BUILDING CODE - BUILDING, 8TH EDITION
2023	(B)	FLORIDA BUILDING CODE - EXISTING, 8TH EDITION
2023	(C)	FLORIDA BUILDING CODE - ACCESSIBILITY, 8TH EDITION
2023	(D)	FLORIDA BUILDING CODE - PLUMBING, 8TH EDITION
2023	(E)	FLORIDA BUILDING CODE - ENERGY, 8TH EDITION
2023	(F)	FLORIDA FIRE PREVENTION CODE, 8TH EDITION
2023	(G)	FLORIDA FIRE PREVENTION CODE - LIFE SAFETY, 2023 EDITION
2023	(H)	FLORIDA BUILDING CODE - MECHANICAL, 8TH EDITION
2023	(J)	NATIONAL ELECTRICAL CODE - NFPA 70
2023	(K)	FLORIDA BUILDING CODE - FUEL GAS, 8TH EDITION

ALTERATION LEVEL - (B) CH. 6
N/A

THRESHOLD BUILDING - (A) CH. 202
N/A

HIGH RISE BUILDING - (A) CH. 403
N/A

USE AND OCCUPANCY CLASSIFICATION - (A) CH. 3; (F) CH. 6 ; (G) CH. 12-43**		
PRIMARY OCCUPANCY: UTILITY AND MISCELLANEOUS GROUP U		
ACCESSORY OCCUPANCY	ADJACENCIES	FIRE SEPARATION - (A) TABLE 508.4, (F) TABLE 6.1.14.4.1
B	S	0 HR. *SEE EXCEPTION
S	B	0 HR. *SEE EXCEPTION

SPECIAL DETAILED REQUIREMENTS BASED ON USE & OCCUPANCY - (A) CH. 4
N/A

TYPES OF CONSTRUCTION - (A) CH. 6			
OCCUPANCY	CONST. TYPE	FIRE-RESISTANCE RATING FOR BUILDING ELEMENTS (TABLE 601)	TYPE 2-B
S	2-B	PRIMARY STRUCTURAL FRAME	0
B	2-B	BEARING WALLS EXTERIOR	0
		BEARING WALLS INTERIOR	0
		NONBEARING WALLS AND PARTITIONS EXTERIOR	0
		NONBEARING WALLS AND PARTITIONS INTERIOR	0
		FLOOR CONSTRUCTION AND SECONDARY MEMBERS	0
		ROOF CONSTRUCTION AND SECONDARY MEMBERS	0

FIRE-RESISTANCE RATING REQUIREMENTS FOR EXTERIOR WALLS BASED ON FIRE SEPARATION DISTANCE- (A) TABLE 602			
	S	B	
X>30'	0	0	

COLUMN PROTECTION - (A) CH. 704.2 : NA

PROTECTION OF THE PRIMARY STRUCTURAL FRAME OTHER THAN COLUMNS - (A) CH. 704.3 : NA

EXTERIOR STRUCTURAL MEMBERS - (A) CH. 704.10: NA

GENERAL BUILDING HEIGHTS AND AREAS - (A) CH. 5			
ALLOWABLE HEIGHT, STORIES, AND AREA : 2B, NON-SPRINKLERED			
OCCUPANCY	HEIGHT (FT) (A) TABLE 504.3	STORY (A) TABLE 504.4	AREA (SF) (A) 506.2
S	55'	2	17,500
B	55'	4	23,000
ACTUAL HEIGHT, STORIES AND AREA			
OCCUPANCY	HEIGHT (FT)	STORY	AREA (SF)
S	18'	1	17,500
B	18'	1	23,000

FIRE AND SMOKE PROTECTION FEATURES - (A) CH. 7	
EXTERIOR WALLS - (A) CH. 705	
PROJECTIONS: SHALL NOT EXTEND CLOSER TO FSD THAN (A) TABLE 705.2:	NA
FIRE-RESISTANCE RATINGS - (A) CH. 705.5:	NA
MAXIMUM AREA OF EXTERIOR WALL BASED ON FIRE SEPARATION DISTANCE (A) TABLE 705.8:	
GREATER THAN 30' - NO LIMIT	
VERTICAL SEPARATION OF OPENINGS (A) CH. 705.8.5:	NA
FIRE WALLS (A) CH. 706:	NA
FIRE BARRIERS (A) CH. 707, (G) 8.3:	NA
FIRE PARTITIONS (A) CH. 708:	NA
SMOKE BARRIERS (A) CH. 709, (G) 8.5:	NA
SMOKE PARTITIONS (A) CH. 710, (G) 8.4:	NA
FLOOR AND ROOF ASSEMBLIES (A) CH. 711:	NA
VERTICAL OPENINGS (A) CH. 712, (G) 8.6:	NA
FIRE-RESISTANCE RATING OF SHAFTS (A) CH. 713.4, (G) 8.6.4:	NA
ELEVATOR LOBBIES (A) CH. 3006:	NA
CONCEALED SPACES (A) CH. 718:	NA
FIREBLOCKING (A) CH. 718.2:	
DRAFTSTOPPING IN FLOORS (A) CH. 718.3:	
N/A - ONE STORY (NON-SPRINKLERED)	
DRAFTSTOPPING IN ATTICS (A) CH. 718.4:	
N/A - NO ATTICS	
FIRE AREAS (A) CH. 707.3.10: 4HR	

INTERIOR FINISHES - (A) CH. 8 ; (G) CH. 12.3 - 43.3**				
INTERIOR WALL AND CEILING FINISH REQUIREMENTS BY OCCUPANCY (TABLE 803.11)				
	OCCUPANCY	EXITING ELEMENTS	CORRIDORS	ROOM & ENCLOSED SPACES
	S	B	B	C
	B	A	B	C

FIRE PROTECTION SYSTEMS - (A) CH. 9 ; (B) CH. 703, 804, 904; (G) 12-43	
AUTOMATIC SPRINKLER SYSTEMS (A) CH. 903	
N/A	
PORTABLE FIRE EXTINGUISHERS - WHERE REQUIRED (A) 906.3.1 (G 13.6.1.2)	
S - CLASS A, ORDINARY HAZARD	
B - CLASS A, ORDINARY HAZARD	
CLASS A, ORDINARY HAZARD FIRE EXTINGUISHER REQUIREMENTS (A) 906.1	
RATED: 2-A	
MAX. FLOOR AREA PER UNIT OF A = 1,500 SF	
MAX. FLOOR AREA FOR EXTINGUISHER = 11,250 SF	
MAX. TRAVEL DISTANCE = 75 FT	
FIRE ALARM AND DETECTION SYSTEMS - WHERE REQUIRED (A) 907.2	
GROUP B - OL> 100, DOES NOT CONTAIN AMBULATORY CARE FACILITY	
NOT INSTALLED PER IBC AND NFPA 72	

MEANS OF EGRESS - (A) CH. 10; (G) CH. 7
OCCUPANT LOAD (A) TABLE 1004.5 (G) TABLE 7.3.1.2: SEE LIFE SAFETY SHEET X-XXX FOR FLOOR PLAN SHOWING OCCUPANT LOADS FOR EACH ROOM
MEANS OF EGRESS SIZING (A) CH. 1005: 0.3" x OL FOR STAIRS AND 0.2" x OL FOR OTHER EGRESS COMPONENTS. SEE LIFE SAFETY SHEET X-XXX FOR FLOOR PLAN SHOWING STAIRS AND EGRESS COMPONENTS AND WIDTH REQUIRED AND WIDTH PROVIDED.

MAXIMUM COMMON PATH OF EGRESS TRAVEL DISTANCE (A) TABLE 1006.2.1 ; (G) 12.2.5 - 43.2.5	
S	75' (WITHOUT SPRINKLER SYSTEM)
B	75' (WITHOUT SPRINKLER SYSTEM)

ACCESSIBLE MEANS OF EGRESS (A) CH. 1009 (C) 206.2.4
NEED (1) ACCESSIBLE MEANS OF EGRESS/SPACE MIN. OR (2) WHEN TWO EXITS ARE REQUIRED.

EXIT TRAVEL DISTANCE (A) TABLE 1017.2 ; (G) 12.2.6 - 43.2.6	
S	200' (WITHOUT SPRINKLER SYSTEM)
B	200' (WITHOUT SPRINKLER SYSTEM)

CORRIDOR FIRE-RESISTANCE RATING (A) TABLE 1020.2	
S	N/A
B	N/A

MINIMUM CORRIDOR WIDTH (A) TABLE 1020.3	
ANY FACILITIES NOT LISTED BELOW -	44"

MEANS OF EGRESS - (A) CH. 10	
DEAD END TRAVEL DISTANCE (A) CH. 1020.5 ; (G) 12.2.5 - 43.2.5	
S	20' (WITHOUT SPRINKLER SYSTEM)
B	20' (WITHOUT SPRINKLER SYSTEM)

ACCESSIBILITY (C)
SCOPING REQUIREMENTS (C) CH. 2
FACILITY AND SITE REQUIRED TO BE ACCESSIBLE
ACCESSIBLE ROUTE (C) CH. 206
206.2.1 SITE ARRIVAL POINTS: 1 REQUIRED
206.2.2 CONNECTED SPACES: ALL SPACES ARE REQUIRED TO BE ACCESSIBLE AND CONNECTED BY AN ACCESSIBLE ROUTE
ACCESSIBLE ENTRANCES (C) CH. 206.4
206.4.1 PUBLIC ENTRANCES: AT LEAST 60% OF ALL PUBLIC ENTRANCES SHALL BE ACCESSIBLE
OTHER FEATURES AND FACILITIES (C) CH. 213
213.2, 213.2 TOILET AND BATHING FACILITIES: ONE TYPE OF EACH FIXTURE, ELEMENT, CONTROL OR DISPENSER SHALL BE ACCESSIBLE
213.3.1 WATER CLOSET COMPARTMENT: ONE WC MUST BE ACCESSIBLE. IF WC + URINALS > 6, PROVIDE ONE AMBULATORY ACCESS WC
213.3.4 LAVATORIES: AT LEAST 5%, BUT NOT LESS THAN ONE SHALL BE ACCESSIBLE
212 KITCHENS AND KITCHENETTES: SHALL BE ACCESSIBLE

INTERIOR ENVIRONMENT (A) CH. 12
VENTILATION (A) CH. 1203
1203.2 VENTILATION REQUIRED: THE NET FREE VENTILATING AREA SHALL BE NOT LESS THAN 1/150 OF THE AREA OF THE SPACE VENTILATED
EXCEPTION #1: 1/300 ALLOWED WHEN 50%-80% OF VENTING AREA IS 3' ABOVE EAVE VENT
EXCEPTION #2: 1/300 ALLOWED WHEN CLASS I OR II VAPOR BARRIER PROVIDED

PLUMBING SYSTEMS (A) CH. 29								
MINIMUM NUMBER OF REQUIRED PLUMBING FIXTURES (A) TABLE 2902.1								
OCC. TYPE	OCC. LOAD	WATER CLOSETS		LAVATORIES		DF	SERVICE SINK	
		M	W	M	W			
S	M-2, W-2	2/100=0.02	2/100=0.02	2/100=0.02	2/100=0.02	2/1000=0.002	1	
B	M-1, W-1	1/25=0.008	1/25=0.008	1/40=0.025	1/40=0.025	2/100=0.02		
PARKING	M-16, W-16	16/25=0.64	16/25=0.64	16/40=0.40	16/40=0.40	32/100=0.32		
	TOTAL REQ.	0.668	0.668	0.445	0.445	0.342	1	
	PROVIDED	2 WC - 1 U	3	3	3	2	2	

FLOOR DRAINS (D) CH. 413 - REFER TO PLANS
INTERCEPTORS/SEPARATORS (D) CH. 1003:
GREASE - NR
OIL - NR
LAUNDRY - NR

THERMAL ENVELOPE (E) TABLE C402.1.3
CLIMATE ZONE (E) TABLE C301.1
OPAQUE THERMAL ENVELOPE REQUIREMENTS (E) TABLE C402.1.3
ROOF: R-30ci
WALLS: R-5.7ci
FLOORS: R-0
SLAB ON GRADE FLOORS: NR
FENESTRATION THERMAL ENVELOPE REQUIREMENTS (E) TABLE C402.1.4
FIXED FENESTRATION: U-0.50
OPERABLE FENESTRATION: U-0.65
ENTRANCE DOORS: U-0.83
SHGC: U-0.25

PROJECT LEAD & CIVIL ENGINEERING:
KEITH
301 EAST ATLANTIC BLVD.
POMPANO BEACH, FL 33060
PH: (954) 788-3400
Florida Engineering Business License: CA7928
Florida Surveyor and Mapper Business License: LB6860
Florida Landscape Architecture Business License: LC26000457

LANDSCAPE ARCHITECT:
MKSK
801 INTERNATIONAL PARKWAY
LAKE MARY, FL 32746
407.871.9607
MKSKSTUDIOS.COM

ARCHITECT:
WANNEMACHER JENSEN ARCHITECTS
815 NORTHWEST 57 AVE. SUITE 219
MIAMI, FLORIDA 33126
727-822-5566
W.JARC.COM AA0002277

MECHANICAL, PLUMBING, & ELECTRICAL ENGINEERING:
SGM ENGINEERING
5301 WATERFORD DISTRICT DR.
SUITE 750
954-421-1944
SGMENGINEERING.COM CA-00006208

REVISIONS

NO.	DESCRIPTION	DATE

PRELIMINARY PLAN NOT FOR CONSTRUCTION

THESE PLANS ARE NOT FULLY PERMITTED AND ARE SUBJECT TO REVISIONS MADE DURING THE PERMITTING PROCESS. RESPONSIBILITY FOR THE USE OF THESE PLANS PRIOR TO OBTAINING PERMITS FROM ALL AGENCIES HAVING JURISDICTION OVER THE PROJECT WILL FALL SOLELY UPON THE USER.

ISSUE DATE:
DESIGNED BY:
DRAWN BY:
CHECKED BY:

NATALIA LIVIAN
AR 97614

CLIENT
VILLAGE OF PINECREST
PINECREST PARKS & RECREATION

PROJECT
GARY MATZNER PARK

SHEET TITLE
CODE ANALYSIS

60% CONSTRUCTION DOCUMENTS

SHEET NUMBER A-002

KEITH PROJECT NUMBER 13861.00

STATUS: PRELIMINARY

Plotted by: davidp On —

Drawing name: P:\2347 Gary Matzner Park\06 PRODUCTION\01 BIM\CAD LINKS\2024.0711 - Citizen Title Block Edited\KR-GMP-TTLBK.dwg