

POWER VENTILATOR SCHEDULE															
MAR-K	SPACE SERVED	CFM	ESP (IN WG.)	DRIVE	FAN RPM	MOTOR		ELECTRICAL		SCONES	MOUNTING	CONTROLS	MANUFACTURER	MODEL	NOTES
						POWER (W)	RPM	VOLTAGE	PHASE						
EP-1	RESTROOM	210	0.25	DIRECT	865	48	865	120	1	1.5	CEILING	ON/OFF W/ LIGHTS	GREENHECK	SPA-200	1-4
EP-2	JANITOR	70	0.25	DIRECT	2125	26.9	2125	120	1	0.8	CEILING	CONTINUOUS	NUTONE	ABN60	3-6
EP-3	STORAGE	210	0.25	DIRECT	865	48	865	120	1	1.5	CEILING	CONTINUOUS	GREENHECK	SPA-200	1-4

NOTES:

1. PROVIDE DECORATIVE GRILLE



2. CONTROL WITH ROOM LIGHTS


3. PROVIDE WITH BACKDRAFT DAMPER

4. PROVIDE WITH SPEED CONTROLLER

5. PROVIDE CORROSION RESISTANT COATING

6. PROVIDE ALUMINUM GRILLE





JOHN STELLPLUG - FL68794

SGM

ENGINEERING

935 LAKE BALDWIN LANE
ORLANDO, FL 32814
TEL: 407-767-5188
FAX: 407-767-5772
CA-00006208

SGM #:

2024-256

COPYRIGHT ©2024

WWW.SGMENGINEERING.COM

SGM ENGINEERING, INC.

ARCHITECT:

WA

WANNEMACHER JENSEN ARCHITECTS
815 NORTHWEST 57 AVE. SUITE 219
MIAMI, FLORIDA 33126
77-1032-5556
WJARC.COM AA0002277

**MECHANICAL, PLUMBING,
& ELECTRICAL ENGINEERING:**

SGM
ENGINEERING

5301 WATERFORD DISTRICT DR.
SUITE 750
954-671-1844
SGMENGINEERING.COM CA-00006208

[illegible]

**PRELIMINARY PLAN
NOT FOR CONSTRUCTION**
THESE PLANS ARE NOT FULLY PERMITTED
AND ARE SUBJECT TO REVISIONS MADE
DURING THE PERMITTING PROCESS.

ISSUE DATE:	XX/XX/20XX
DESIGNED BY:	XXX
DRAWN BY:	XXX
CHECKED BY:	XXX

THOMAS F. DONAHUE, P.E.
FLORIDA REG. NO. 60529
(FOR THE FIRM)

CLIENT
VILLAGE OF
PINECREST
PINECREST PARKS & RECREATION

PROJECT

SHEET TITLE

MECHANICAL
SCHEDULES &
DETAILS

SHEET
NUMBER M701

KEITH PROJECT
NUMBER 13861.00