

E

D

C

B

A

1

2

3

4

5

6

1

2

3

4

5

6

CODE ANALYSIS

SCOPE OF WORK			
THE SCOPE OF WORK INCLUDES A ONE STORY 1,000 G.S.F NON SPRINKLERED BUILDING OF TYPE 3B UNPROTECTED CONSTRUCTION. THE STRUCTURE IS COMPOSED OF LOADBEARING CMU BLOCK WALLS, WOOD TRUSSES AND WOOD RAFTERS. THE INTERIOR WALLS ARE CMU BLOCK AND INTERIOR LIGHT GAUGE METAL FRAMED WALLS. THE PROJECT INCLUDES MECHANICAL EQUIPMENT, PLUMBING, ELECTRICAL. THE TOTAL BUILDING HEIGHT MEASURED FROM FFE TO TOP OF ROOF IS 18'-3 1/2"			
ABBREVIATIONS			
N/A	NOT APPLICABLE AS PART OF THIS PROJECT		
AGP	ABOVE GRADE PLAN - STORY		
FDVA	FIRE DEPARTMENT VEHICLE ACCESS		
FSD	FIRE SEPARATION DISTANCE		
AHJ	AUTHORITY HAVING JURISDICTION		
OL	OCCUPANT LOAD		
APPLICABLE CODES			
2023	(A)	FLORIDA BUILDING CODE - BUILDING, 8TH EDITION	
2023	(B)	FLORIDA BUILDING CODE - EXISTING, 8TH EDITION	
2023	(C)	FLORIDA BUILDING CODE - ACCESSIBILITY, 8TH EDITION	
2023	(D)	FLORIDA BUILDING CODE - PLUMBING, 8TH EDITION	
2023	(E)	FLORIDA BUILDING CODE - ENERGY, 8TH EDITION	
2023	(F)	FLORIDA FIRE PREVENTION CODE, 8TH EDITION	
2024	(G)	FLORIDA FIRE PREVENTION CODE - LIFE SAFETY, 2023 EDITION	
2023	(H)	FLORIDA BUILDING CODE - MECHANICAL, 8TH EDITION	
2023	(J)	NATIONAL ELECTRICAL CODE - NFPA 70	
2023	(K)	FLORIDA BUILDING CODE - FUEL GAS, 8TH EDITION	
ALTERATION LEVEL - (B) CH. 6			
N/A			
THRESHOLD BUILDING - (A) CH. 202			
N/A			
HIGH RISE BUILDING - (A) CH. 403			
N/A			
USE AND OCCUPANCY CLASSIFICATION - (A) CH. 3; (F) CH. 6			
PRIMARY OCCUPANCY: UTILITY AND MISCELLANEOUS GROUP U			
ACCESSORY OCCUPANCY	ADJACENCIES	FIRE SEPARATION - (A) TABLE 508.4, (F) TABLE 6.1.14.4.1	
B	S-2	0 HR. *SEE EXCEPTION	
S-2	B	1 HR. *SEE EXCEPTION	
SPECIAL DETAILED REQUIREMENTS BASED ON USE & OCCUPANCY - (A) CH. 4			
N/A			
TYPES OF CONSTRUCTION - (A) CH. 6			
OCCUPANCY	CONST. TYPE	FIRE-RESISTANCE RATING FOR BUILDING ELEMENTS (TABLE 601)	TYPE 3-B
S-2	3B	PRIMARY STRUCTURAL FRAME	0
B	3B	BEARING WALLS EXTERIOR	2
		BEARING WALLS INTERIOR	0
		NONBEARING WALLS AND PARTITIONS EXTERIOR	0
		NONBEARING WALLS AND PARTITIONS INTERIOR	0
		FLOOR CONSTRUCTION AND SECONDARY MEMBERS	0
		ROOF CONSTRUCTION AND SECONDARY MEMBERS	0
FIRE-RESISTANCE RATING REQUIREMENTS FOR EXTERIOR WALLS BASED ON FIRE SEPARATION DISTANCE- (A) TABLE 602			
	S-2	B	
X>30'	0	0	
COLUMN PROTECTION - (A) CH. 704.2 : NA			
PROTECTION OF THE PRIMARY STRUCTURAL FRAME OTHER THAN COLUMNS - (A) CH. 704.3 : NA			
EXTERIOR STRUCTURAL MEMBERS - (A) CH. 704.10: NA			
GENERAL BUILDING HEIGHTS AND AREAS - (A) CH. 5			
ALLOWABLE HEIGHT, STORIES, AND AREA : 3B, NON-SPRINKLERED			
OCCUPANCY	HEIGHT (FT) (A) TABLE 504.3	STORY (A) TABLE 504.4	AREA (SF) (A) 506.2
S-2	55'	3	26,600
B	55'	3	19,000
ACTUAL HEIGHT, STORIES AND AREA			
OCCUPANCY	HEIGHT (FT)	STORY	AREA (SF)
S-2	18'	1	154
B	18'	1	111

FIRE AND SMOKE PROTECTION FEATURES - (A) CH. 7				
EXTERIOR WALLS - (A) CH. 705				
	PROJECTIONS: SHALL NOT EXTEND CLOSER TO FSD THAN (A) TABLE 705.2: NA			
	FIRE-RESISTANCE RATINGS - (A) CH. 705.5: NA			
MAXIMUM AREA OF EXTERIOR WALL BASED ON FIRE SEPARATION DISTANCE (A) TABLE 705.8:				
	GREATER THAN 30' - NO LIMIT			
VERTICAL SEPARATION OF OPENINGS (A) CH. 705.8.5: NA				
FIRE WALLS (A) CH. 706: NA				
FIRE BARRIERS (A) CH. 707, (G) 8.3: NA				
FIRE PARTITIONS (A) CH. 708: NA				
SMOKE BARRIERS (A) CH. 709, (G) 8.5: NA				
SMOKE PARTITIONS (A) CH. 710, (G) 8.4: NA				
FLOOR AND ROOF ASSEMBLIES (A) CH. 711: NA				
VERTICAL OPENINGS (A) CH. 712, (G) 8.6: NA				
FIRE-RESISTANCE RATING OF SHAFTS (A) CH. 713.4, (G) 8.6.4: NA				
ELEVATOR LOBBIES (A) CH. 3006: NA				
CONCEALED SPACES (A) CH. 718: NA				
	FIREBLOCKING (A) CH. 718.2:			
	DRAFTSTOPPING IN FLOORS (A) CH. 718.3:			
	N/A - ONE STORY (NON-SPRINKLERED)			
	DRAFTSTOPPING IN ATTICS (A) CH. 718.4:			
		N/A - NO ATTICS		
FIRE AREAS (A) CH. 707.3.10: N/A				
INTERIOR FINISHES - (A) CH. 8				
INTERIOR WALL AND CEILING FINISH REQUIREMENTS BY OCCUPANCY (TABLE 803.11)				
	OCCUPANCY	EXITING ELEMENTS	CORRIDORS	ROOM & ENCLOSED SPACES
	S	B	B	C
	B	A	B	C
FIRE PROTECTION SYSTEMS - (A) CH. 9 ; (B) CH. 703, 804, 904				
AUTOMATIC SPRINKLER SYSTEMS (A) CH. 903				
	N/A			
PORTABLE FIRE EXTINGUISHERS - WHERE REQUIRED (A) 906.3.1 (G 13.6.1.2)				
	S - CLASS A, ORDINARY HAZARD			
	B - CLASS A, ORDINARY HAZARD			
CLASS A, ORDINARY HAZARD FIRE EXTINGUISHER REQUIREMENTS (A) 906.1				
	RATED: 2-A			
	MAX. FLOOR AREA PER UNIT OF A = 1,500 SF			
	MAX. FLOOR AREA FOR EXTINGUISHER = 11,250 SF			
	MAX. TRAVEL DISTANCE = 75 FT			
FIRE ALARM AND DETECTION SYSTEMS - WHERE REQUIRED (A) 907.2				
	GROUP B - OL> 100, DOES NOT CONTAIN AMBULATORY CARE FACILITY			
	NOT INSTALLED PER IBC AND NFPA 72			
MEANS OF EGRESS - (A) CH. 10; (G) CH. 7				
OCCUPANT LOAD (A) TABLE 1004.5 (G) TABLE 7.3.1.2: SEE LIFE SAFETY PLAN, SHEET A-100 FOR FLOOR PLAN SHOWING OCCUPANT LOADS FOR EACH ROOM				
MEANS OF EGRESS SIZING (A) CH. 1005: 0.3" x OL FOR STAIRS AND 0.2" x OL FOR OTHER EGRESS COMPONENTS. SEE LIFE SAFETY PLAN, SHEET A-100 FOR FLOOR PLAN SHOWING STAIRS AND EGRESS COMPONENTS AND WIDTH REQUIRED AND WIDTH PROVIDED.				
MAXIMUM COMMON PATH OF EGRESS TRAVEL DISTANCE (A) TABLE 1006.2.1				
	S	75' (WITHOUT SPRINKLER SYSTEM)		
	B	75' (WITHOUT SPRINKLER SYSTEM)		
ACCESSIBLE MEANS OF EGRESS (A) CH. 1009 (C) 206.2.4				
	NEED (1) ACCESSIBLE MEANS OF EGRESS/SPACE MIN. OR (2) WHEN TWO EXITS ARE REQUIRED.			
EXIT TRAVEL DISTANCE (A) TABLE 1017.2				
	S-2	300' (WITHOUT SPRINKLER SYSTEM)		
	B	200' (WITHOUT SPRINKLER SYSTEM)		
CORRIDOR FIRE-RESISTANCE RATING (A) TABLE 1020.2				
	S	N/A		
	B	N/A		
MINIMUM CORRIDOR WIDTH (A) TABLE 1020.3				
	ANY FACILITIES NOT LISTED BELOW - 44"			

MEANS OF EGRESS - (A) CH. 10								
DEAD END TRAVEL DISTANCE (A) CH. 1020.5 ; (G) 12.2.5								
	S	20' (WITHOUT SPRINKLER SYSTEM)						
	B	20' (WITHOUT SPRINKLER SYSTEM)						
ACCESSIBILITY (C)								
SCOPING REQUIREMENTS (C) CH. 2								
	FACILITY AND SITE REQUIRED TO BE ACCESSIBLE							
ACCESSIBLE ROUTE (C) CH. 206								
	206.2.1 SITE ARRIVAL POINTS: 1 REQUIRED							
	206.2.2 CONNECTED SPACES: ALL SPACES ARE REQUIRED TO BE ACCESSIBLE AND CONNECTED BY AN ACCESSIBLE ROUTE							
ACCESSIBLE ENTRANCES (C) CH. 206.4								
	206.4.1 PUBLIC ENTRANCES: AT LEAST 60% OF ALL PUBLIC ENTRANCES SHALL BE ACCESSIBLE							
OTHER FEATURES AND FACILITIES (C) CH. 213								
	213.2, 213.2 TOILET AND BATHING FACILITIES: ONE TYPE OF EACH FIXTURE, ELEMENT, CONTROL OR DISPENSER SHALL BE ACCESSIBLE							
	213.3.1 WATER CLOSET COMPARTMENT: ONE WC MUST BE ACCESSIBLE. IF WC + URINALS > 6, PROVIDE ONE AMBULATORY ACCESS WC							
	213.3.4 LAVATORIES: AT LEAST 5%, BUT NOT LESS THAN ONE SHALL BE ACCESSIBLE							
	212 KITCHENS AND KITCHENETTES: SHALL BE ACCESSIBLE							
INTERIOR ENVIRONMENT (A) CH. 12								
VENTILATION (A) CH. 1203								
	1203.2 VENTILATION REQUIRED: THE NET FREE VENTILATING AREA SHALL BE NOT LESS THAN 1/150 OF THE AREA OF THE SPACE VENTILATED							
	EXCEPTION #1: 1/300 ALLOWED WHEN 50%-80% OF VENTING AREA IS 3' ABOVE EAVE VENT							
	EXCEPTION #2: 1/300 ALLOWED WHEN CLASS I OR II VAPOR BARRIER PROVIDED							
PLUMBING SYSTEMS (A) CH. 29								
MINIMUM NUMBER OF REQUIRED PLUMBING FIXTURES (A) TABLE 2902.1								
OCC. TYPE	OCC. LOAD	WATER CLOSETS		LAVATORIES		DF	SERVICE SINK	
		M	W	M	W			
S	M-2, W-2	2/100=0.02	2/100=0.02	2/100=0.02	2/100=0.02	2/1000=0.002	1	
B	M-1, W-1	1/25=0.008	1/25=0.008	1/40=0.025	1/40=0.025	2/100=0.02		
PARKING	M-16, W-16	16/25=0.64	16/25=0.64	16/40=0.40	16/40=0.40	32/100=0.32		
	TOTAL REQ.	0.668	0.668	0.445	0.445	0.342	1	
	PROVIDED	2 WC - 1 U	3	3	3	2	2	
FLOOR DRAINS (D) CH. 413 - REFER TO PLANS								
INTERCEPTORS/SEPARATORS (D) CH. 1003:								
GREASE - NR								
OIL - NR								
LAUNDRY - NR								
THERMAL ENVELOPE (E) TABLE C402.1.3								
CLIMATE ZONE (E) TABLE C301.1								
OPAQUE THERMAL ENVELOPE REQUIREMENTS (E) TABLE C402.1.3								
	ROOF: R-30ci							
	WALLS: R-5.7ci							
	FLOORS: R-0							
	SLAB ON GRADE FLOORS: NR							
FENESTRATION THERMAL ENVELOPE REQUIREMENTS (E) TABLE C402.1.4								
	FIXED FENESTRATION: U-0.50							
	OPERABLE FENESTRATION: U-0.65							
	ENTRANCE DOORS: U-0.83							
	SHGC: U-0.25							

PROJECT LEAD & CIVIL ENGINEERING:



301 EAST ATLANTIC BLVD.
POMPAN0 BEACH, FL 33060
PH: (954) 788-3400
Florida Engineering Business License: CA7928
Florida Surveyor and Mapper Business License: L86880
Florida Landscape Architecture Business License: LC2880647

LANDSCAPE ARCHITECT:



801 INTERNATIONAL PARKWAY
LAKE MARY, FL 32746
407.871.9807
MKS KSTUDIOS.COM

ARCHITECT:



WANNEMACHER, JENSEN ARCHITECTS
815 NORTHWEST 57 AVE. SUITE 219
MIAMI, FLORIDA 33126
727-492-5568
WJARG.COM AA0002277

MECHANICAL, PLUMBING, & ELECTRICAL ENGINEERING:



5301 WATERFORD DISTRICT DR.
SUITE 750
954-421-1944
SGMENGINEERING.COM CA-0000