



July 8, 2025

Subject: Response to Round 4 Comments from Miami-Dade County
Project: 7800 SW 110th Street (M2024012896)

To Whomever it May Concern:

We have reviewed the Cycle 4 comments made by the Miami-Dade County Department of Health for the above referenced project and have revised our plans accordingly. We would like to offer the following responses to the comments.

Department of Health - Vida Talab

3. **Plan C-100:** Paving, Grading, and Drainage. Plan C-100 shows retention areas close to the proposed septic system. As it is proposed with the use of water retention, it is considered a retention area. Please revise or delete.

Response: The retention area adjacent south of the septic tank has been deleted from sheet C-100 and the drainage calculations.

Please let us know if you have any questions or need additional information.

Sincerely,

TERRA CIVIL ENGINEERING, LLC

By: 
Marco A. Osorio, P.E., MBA