

DG CONSULTING ENGINEERS, LLC

January 20, 2025

Miami Building Department
Mechanical
Miami, Florida

Re:

10635 SW 63 AV
Miami, Florida

To whom it may concern:

The following are the responses for the above referenced Mechanical permit plan reviewer comments.

Mechanical

Comment #1: Provide motorized dampers for all outside air intake.

Response: Please see sheet M-101 for Motorized damper at air intake.

Comment #2: Comply with balanced air return section 6 FBC-M.

Response: Please see sheet M-101 & M-102 Balnce air return revised.

Should you have any questions or require additional information please contact me at the address or phone below.

Sincerely,



Daniel F. Gutierrez, P.E.