

10635 SW 63 AV
MIAMI, FL

LI-TRAUTMAN ARCHITECTS LLC -AA2600296

REVISIONS

SCALE: AS NOTED

TYP. DETAIL AND CHEDULES

SGN-2

COPYRIGHT BALLI-TRAUTMAN ARCHITECTS,
LLC
1533 SUNSET DRIVE SUITE 101, CORAL GABLES,
FL 33143

CORNER BARS SAME SIZE & LAP PER GSN OR SCHEDULE. PROVIDE STANDARD HOOK & ALTERNATE BEND DIRECTION @ INTERSECTION

VERTICAL REINF. AT CENTER OF WALL UNO ON PLAN

WIRE POSITIONED (SPIDER CLIP) OR TIE AT 8'-0" VERTICALLY

9 GAGE LADDER TYPE @ 16"

ISOMETRIC

PLAN - CORNER

48" (MP)

HORIZ. REINF. PER GSN OR PLAN OR DETAIL

HORIZ. REINF. PER GSN OR PLAN OR DETAIL

HORIZ. REINFORCING PER GSN OR PLAN OR DETAIL

HORIZ. REINFORCING PER GSN OR PLAN OR DETAIL

PLAN - INTERSECTION

NOTE: 1. VERT REINFORCING AND GROUT NOT SHOWN FOR CLARITY
2. AT DOUBLE HORIZ. REINF. PROVIDE CORNER BAR FOR EACH HORIZ BAR

TIE DOWN SEE PLAN

8" OR 12" C.M.U.

1x4 P.T. WOOD BUCK W/ 3/16"x2 3/4" TAPCON SCREWS @ 4" O.C. FROM THE END & 24" O.C. MAX ELSEWHERE EMBEDDED IN CAULKING (1 1/2" MIN. EMBEDMENT INTO MASONRY).

1 #5 IN CONC. FILLED CELLS PROVIDE DOWELS AT FOOTING OR THICKENED SLAB & EXTEND TOP OF BAR 8" INTO CONC. TIE BEAM ABOVE W/ 6" HOOK.

WINDOWS AND DOORS INSTALLATION SHALL BE IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS AS SET FORTH IN THE APPROVED NOTICE OF ACCEPTANCE.

SCALE: N.T.S.









Diagram illustrating a standard hook for reinforcement bars. The hook is shown embedded in concrete, with labels indicating the tension, embedment, standard hook, face of concrete, and the diameter of the bar (12 BAR DIA.).

NO SCALE

TENSION LAP SPLICES					
F _c (PSI)	4000	5000	6000	7000	8000
BAR SIZE					
#4	37"	33"	30"	29"	26"
#5	47"	42"	37"	36"	33"
#6	56"	50"	44"	43"	39"
#7	81"	73"	65"	63"	57"
#8	93"	83"	73"	71"	65"
#9	105"	94"	83"	54"	74"
#10	116"	106"	96"	90"	83"



Zvonimir T. Belfranin, P.E.
Consulting Structural Engineer
P.E. # 33074
4836 S.W. 74 CT., MIAMI, FLORIDA 33155
(305) 669-0255
BELFRANIN@AOL.COM