

Zvonimir T. Belfranin, P.E.
Consulting Structural Engineer
4836 S.W. 74th Court
Miami, Florida 33155
(305) 669-0255
Fax (305) 669-1073
E-mail : belfranin@aol.com

March 19, 2025

**Att : Building Official
Building & Zoning
Village of Pinecrest
Florida**

**Re: 10635 S.W. 63 Avenue
B.L. 2024-1665**

Response to Comments :

- 1. W12 footing clarified as WF-36 on S-101.**
- 2. Column C12 corrected in lieu of C2.**
- 3. Please refer to Section 1/S-101.**
- 4. Reactions and connectors provided on S-102 & S-104.**
- 5. Blocking has been provided @ 4'-0" max. See detail on S-104.**
- 6. Sheet SGN attached with general notes and details.**