



COMMENT RESPONSE SHEET – 10635 SW 63th Ave.

PERMIT / PROCESS NUMBER: City of Pinecrest_ BL2024-1665

DATE: 04-17-2025

BUILDING

4/10/2025 4:25:08 PM ***PENDING OUTSIDE AGENCY APPROVAL; AS OF TODAY HRS REVIEW IS PENDING FOR PROCESS # M2025004680 1. COORDINATION; CHANGE ENERGY CALCULATION FROM ELECTRIC TANKLESS W.H. TO GAS TO MATCH PLUMBING DRAWINGS.

a. Waiting for the approval of outside agencies. Coordination has been made. Please refer to sheet to tankless water heater diagram in P-106 and the energy calculation document.