SGM ENGINEERING

935 Lake Baldwin Lane
Orlando, FL 32814
(407) 767-5188
(407) 767-5772 fax
www.sgmengineering.com

1991 - 2025
34
YEARS OF EXCELLENCE
SGM ENGINEERING

April 10, 2025

Gary Matzner Park
SGM Project #2024-256

RE: Revision 1 Narrative

M701 – Added Natural Ventilation Compliance Calculations table.

E101 – Revised transformer from pad mounted to pole mounted. Revised light/camera locations based on walkway update.
E701 – Revised fountain to 240V. Revised service to 240V. Revised fault current letter and fault current calcs based on service change to 240V.