

Notes: BUILDING

COMMENTS:

PROVIDE A SURVEY w/ COR VALUES

SEE ATTACHED NEW SURVEY W/COR VALUES

-DERM APPROVAL REQUIRED

TO BE SUBMITTED BUILDING DEPARTMENT MIAMI DADE (DERM)

-HEALTH DEPARTMENT

TO BE SUBMITTED BUILDING DEPARTMENT MIAMI DADE (DERM)

-WASD CP

TO BE SUBMITTED BUILDING DEPARTMENT MIAMI DADE (DERM)

APPROVAL REQUIRED

-IMPACT FEE REVIEW

IMPACT FEE REVIEW TO BE REVIEWED

1. SP-1: IDENTIFY ALL SITE FEATURES AND CROSS-REFERENCE TO APPLICABLE DETAILS OR NOTE AS BY SEPARATE PERMIT, EX, DRIVEWAY, POOL DECK, LP TANKS, FENCES & WALLS.
SEE NEW CHANGES ON SHEET SP-1
2. 3/A-7.2: UPDATE/CORRECT EGRESS REQUIREMENTS TO CURRENT CODE.
SEE NEW CORRECTION ON SHEET A-7.2
3. @ DOOR #D02 LANDING TO COMPLY w R311.3.
SEE NEW CHANGES ON SHEET A-1 @ DOOR #D02
4. COORDINATE ENERGY CALCS w/ ACTUAL PROPOSED WORK. NOTE ATTIC INSULATION COMPLIANCE REQUIRED UNDER ROOF SLAB-SEE NOTE A-2.0.
SEE NEW CHANGES ON SHEET A-2.0

REVIEW PLANS FOR COMPLETENESS AND ACCURACY.