

Notes: ELECTRICAL

COMMENTS:

- 1- PLEASE ADD CO ALARMS TO PLANS. FBC R315.
SEE NEW CHANGES ON SHEET E-1 AND E-2
- 2- TYPICALLY, YOU CAN INTERCONNECT UP TO 12 SMOKE ALARMS TOGETHER BY LISTING. PLEASE SPECIFY IF YOU ARE USING A FIRE ALARM SYSTEM OR SPEC ALARMS THAT ALLOW MORE THAN 12 TO BE INTERCONNECTED.

WE WANT TO USE A SPEC ALARM
- 3- SHEET E-3 NOTE 1 SHOWS 2017 NEC. PLEASE CORRECT THE CURRENT CODE IS THE 2020 NEC.

SEE NEW CHANGES ON SHEET E-3 NOTE 1
- 4- GFCI PROTECTION MISSING. PLEASE CORRECT PLANS TO INCLUDE ALL OUTLETS REQUIRED BY THE 2020 NEC 210.8(A) DWELLING UNITS. ALL 125-VOLT THROUGH 250-VOLT RECEPTACLES INSTALLED IN THE LOCATIONS SPECIFIED IN 210.8(A)(1) THROUGH (A)(11) AND SUPPLIED BY SINGLE-PHASE BRANCH CIRCUITS RATED 150 VOLTS OR LESS TO GROUND
SEE NEW CHANGES ON SHEET E-1.1 AND E-2.1