

Notes: PLUMBING

COMMENTS:

PENDING OUTSIDE AGENCIES.

PLANS TO BE SEND BUILDING DEPARTMENT MIAMI DADE (DERM)

2. INDICATE COMPLIANCE WITH NFPA 58 &#167; 6.4.4.3, PROVIDE ON PLAN DISTANCE OF PROPOSED TANK TO SOURCES OF IGNITION AND INTAKES. CONTAINERS FILLED ON SITE MUST BE LOCATED SO THAT THE FILLING CONNECTION AND FIXED MAX. LIQUID LEVEL GAUGE ARE AT LEAST 10 FT FROM ANY EXTERIOR SOURCE OF IGNITION (E.G., OPEN FLAME, WINDOW AC, COMPRESSOR), INTAKE TO DIRECT-VENTED GAS APPLIANCE, OR INTAKE TO A MECHANICAL VENTILATION SYSTEM.

SEE NEW NOTE ON SHEET G-1, AND SEE NEW CHANGES ON SHEET G-1,SP-1,AND LP-1