

Notes: STORM DRAINAGE

COMMENTS:

- 1- THE SURVEY PLAN MUST HAVE ELEVATIONS AND/OR TOPOGRAPHIC PROVIDED TO PREPARE OR CHECK A STORMWATER MANAGEMENT SYSTEM.
SEE ATTACHED NEW SURVEY WITH NEW ELEVATIONS OR TOPOGRAPHIC
- 2- THE SURVEY SUBMITTED HAS NONE.
SEE ATTACHED NEW SURVEY WITH NEW ELEVATIONS OR TOPOGRAPHIC
- 3- THE SHEET S-P.1 MADE REFERENCE TO NOTES NOT SHOWN ON PLANS.
SEE NEW CHANGES ON SHEET SP-1 AND C1
- 4- MUST COMPLY WITH THE FOLLOWING VOP REQUIREMENTS FOR DRAINAGE PLANS: 1) PROVIDE DRAINAGE CALCULATIONS AND MUST COMPLY WITH THE FOLLOWING: 2) SEE VILLAGE OF PINECREST WEBSITE FOR STORMWATER MANAGEMENT REQUIREMENTS.
SEE NEW CHANGES ON SHEET C1, SP-1 LP-1 SPD-1