

COMMENTS: MECHANICAL

Notes:

4/9/2025 7:32:52 AM

LAUNDRY ROOM MUA FROM OUTSIDE?

SEE NEW CHANGES SHEET M-2

EF-2 ON SCHEDULE SAYS 110 CFM, ON FIELD PLAN SAYS 600 CFM.

SEE NEW CHANGES ON SHEET M-1

NEED RETURN AIR FOR ALL ROOMS SERVED BY AHU-2.

SEE NEW CHANGES ON SHEET M-1