

COMMENTS: STORM DRAINAGE

Notes:

4/24/2025 10:56:26 AM

No

tes:

1. THE SURVEY PLAN MUST HAVE ELEVATIONS AND/OR TOPOGRAPHIC PROVIDED TO PREPARE OR CHECK A STORMWATER MANAGEMENT SYSTEM. THE SURVEY SUBMITTED HAS NONE.

SEE ATTACHED NEW SURVEY

2. THE SHEET S-P.1 MADE REFERENCE TO NOTES NOT SHOWN ON PLANS

SEE NEW SITE PLAN

3. MUST COMPLY WITH THE FOLLOWING VOP REQUIREMENTS FOR DRAINAGE PLANS: 1) PROVIDE DRAINAGE CALCULATIONS AND MUST COMPLY WITH THE FOLLOWING: 2) SEE VILLAGE OF PINECREST WEBSITE FOR STORMWATER MANAGEMENT REQUIREMENTS.

[HTTPS://LIBRARY.MUNICODE.COM/FL/PINECREST/CODES/CODE_OF_ORDINANCES?NODEID=COORVPIFL_CH30LADERE_ART6ENRE_DIV_6.15STMA](https://library.municode.com/fl/pinecrest/codes/code_of_ordinances?nodeid=coorvipfl_ch30ladere_art6enre_div_6.15stma)

SEE ATTACHED NEW CALCULATION

