

BUILDING. Reviewer: ORESTE GARCIA

6/20/2025 9:25:34 AM

Notes:

1. GENERATOR LOCATION MUST BE 10' AWAY FROM OPERABLE WINDOW. CONFIRM COMPLIANCE TO 2ND FLOOR BEDROOM WINDOW. ***Location of the generator exhaust with respect to exterior wall openings in the building. The generator exhaust shall be located 10 feet away from wall openings such as windows, doors, exhaust fans, appliance vents, etc. in accordance with the requirements of the Florida Residential Code, section R1602.2.

SEE NEW CHANGES ON A-1