

PUBLIC WORKS

Date

Completed: 6/13/2025, 4:28:29 PM

Reviewer: DAVID MENDEZ

1. N/A
2. NO LANDSCAPE PLANS PROVIDED. PW APPROVAL WILL NOT BE PROVIDED UNTIL THE LANDSCAPE PLANS FOR THE ROW HAVE BEEN REVIEWED AND APPROVED BY PW.
SEE NEW LANDSCAPING PLAN ATTACHED
 - A. (6-13-25: PROVIDE THE OFFSET FROM THE EOP TO THE FACE OF THE PROPOSED STREET TREE.
 - i. **SEE NEW LANDSCAPING PLAN**
 - B. CALL OUT SAND GROWN EMPIRE ZOYSIA.
 - i. **SEE NEW CHANGE ON SHEET LP-1 AND C-1**
 - C. CORRECT THE SPELLING OF JUMBO – GUMBO.
 - i. **SEE NEW CORRECTION ON SHEET LP-1**
3. C1: INCLUDE ALL OF THE LATEST DETAILS – CURRENT DETAILS PROVIDED ARE OUT OF DATE. (6-13-25: SWALE DETAIL IS OUT OF DATE.
SEE NEW SWALE DETAIL ON SHEET C-1
4. C1: CALL OUT SAND GROWN EMPIRE ZOYSIA FOR THE SWALE.
SEE NEW CHANGES ON SHEET C-1
5. C2: THE CONSTRUCTION ENTRANCE IN THE PLAN MUST BE THE SAME AS THE DETAIL. THE BALLAST ROCK WILL GO FROM THE EOP TO 30' INSIDE THE PROPERTY.
SEE NEW CHANGES ON SHEET C2 AND SPD-2
6. C2: D/W APPROACH IS SHOWN AS PLAIN CONCRETE IN C1/SECTION DD, BUT AS A BLOCK D/W IN C2- CAN ONLY BE ONE TYPE.
SEE NEW CHANGES ON SHEET C-2