

PUBLIC WORKS - DAVID MENDEZ.

8/21/2025 4:43:43 PM

1. No comment

2. No Landscape Plans provided. PW approval will not be provided until the landscape plans for the ROW have been reviewed and approved by PW. a. (b. c. d. Provide spacing between proposed oaks in the ROW. Minimum spacing of street trees is 30'.

DONE - PLEASE SEE LP-1 REV-4

3. No comment

4. No Comment

5. C2: the construction entrance in the plan must be the same as the detail. The ballast rock will go from the EOP to 30' inside the property.(8-21-25: TOTAL length of the ballast rock must be 50' – with 30' INSIDE the property.)

DONE - PLEASE SEE SPD-2 REV-3

6. No comment

7. D-1 does not show the location of the temporary construction entrance.

DONE: PLEASE REFER TO D-1 REV-1