



VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156

PERMIT # BL-2022-1876
JOB ADDRESS 9321 SW 67 AVE

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
100	GL1R	34"X 141"	ES8000T	FL# 17897.5	54	42	70	60
101	GL2R	94"X 141" OO	ES8000T	FL#17897.5	46	42	70	70
102	GL2R	45"X 141'	ES8000T	FL#17897.5	54	42	70	70
104	GL1R	46"X 125"	ES8000T	FL#17897.5	55	42	70	60
105	GL1R	46"X 26"	ES8000T	FL#17897.5	63	47	70	60
106	GL1R	26"X 85"	ES8000T	FL#17897.5	60	46	70	60
106	N/A	2X6X 26"	Legacy Mullions	FL#21144.2	60	46	150	150
107	GL1R	26"X 89"	ES8000T	FL#17897.5	50	46	70	60
109	GL1R	26"X 81"	ES8000T	FL#17897.5	58	45	70	60
111	GL1R	31"X 113"	ES8000T	FL#17897.5	56	44	70	60
114	GL2R	150"X 141"OOO	ES8000T	FL#17897.5	54	42	70	70
117	Di	124"X 23"	ES-150 FIXED	23-0714.17	47	43	80	80
118	Di	123"X 23"	ES-150 FIXED	23-0714.17	47	43	80	80
120	GL2R	22"X 141"	ES8000T	FL#17897.5	56	44	70	60
121	GL2R	80"X 141"OO	ES8000T	FL#17897.5	54	42	70	60
122	GL2R	46"X 141"	ES8000T	FL#17897.5	46	42	70	70
123	GL2R	110"X 141"OO	ES8000T	FL#17897.5	46	42	70	70
124	GL2R	35"X 141"	ES8000T	FL#17897.5	54	42	70	70
130A	GL25	170"X 24"OOO	ES8000T	FL#17897.5	54	40	70	60

- 1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.
- 2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)



VILLAGE OF PINECREST
Building & Planning Department
12645 Pinecrest Parkway,
Pinecrest, Florida 33156

PERMIT # BL-2022-1876

JOB ADDRESS 9321 SW 67 Ave

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
131	GL2R	63"X 118"	ES-8000T	FL# 17897.5	54	43	70	70
131	N/A	2X6X 118"	MULLION	24-0312.06	54	43	70	70
131A	GL1R	63"X 24"	ES-8000T	FL#17897.5	63	47	70	60
200	GL1R	52"X 118"	ES-8000T	FL# 17897.5	63	42	70	60
201	GL1R	34"X 118"	ES-8000T	FL# 17897.5	54	43	70	60
202	GL1R	91"X 118"OO	ES-8000T	FL# 17897.5	55	44	70	60
203	Di	97"X 23"	ES-150-FIXED	23-0714.17	58	43	80	80
204B	Di	98"X 23"	ES-150-FIXED	23-0714.17	58	45	80	80
204	GL2R	58"X 86"	ES-8000T	FL# 17897.5	55	45	60	60
204A	GL2R	58"X 86"	ES-8000T	FL# 17897.5	55	43	60	60
209	Di	134"X 23"	ES-8000T	FL# 17897.5	47	43	80	80
210	Di	137"X 23"	ES-8000T	FL# 17897.5	47	43	80	80
212	GL1R	29"X 81"	ES-8000T	FL# 17897.5	56	44	70	60
213	GL1R	24"X 81"	ES-8000T	FL# 17897.5	55	43	70	60
214	GL1R	35"X 118"	ES8000T	FL# 17897.5	56	44	70	60
131A	N/A	2X6X 24"	MULLION	23-0312.06	63	47	150	150

- 1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.
- 2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)



VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156

PERMIT # _____

JOB ADDRESS _____

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
101	E	34"X 119"	9000 O/S	FL# 22527.2	56	44	90	90
102	E	34"X 108"	9000 O/S	FL# 22527.2	58	45	90	90
110	G2	70"X 120" XX	2020 SGD	FL# 22267.1	56	44	150	53
103	E	34"X 119"	9000 O/S	FL# 22527.2	56	44	90	90
113	G1	201"X 144"oxxo	2020 SGD	FL# 22267.1	54	43	102	53
115	G1	354"X 144"oxx-xxo	2020 SGD	FL# 22267.1	54	43	102	53
116	G1	185"X 144"oxxo	2020 SGD	FL# 22267.1	54	43	102	53
192	E	35"x 119"	9000 O/S	FL# 22527.2	56	44	90	90
169	E	34"x 119"	9000 O/S	FL# 22527.2	46	36	90	90
170	E	34"x 119"	9000 O/S	FL# 22527.3	48	37	90	90
130	G3	177"x 120"xxx	2020 SGD	FL# 22267.1	40	37	102	53
205	G3	263"x 120"oxx-xo	2020 SGD	FL# 22267.1	55	43	102	53
206	G3	155"x 120"xxx	2020 SGD	FL# 22267.1	55	43	102	53
207	G3	153"x 120"xxx	2020 SGD	FL# 22267.1	47	43	102	53
208	G3	153"x 120"xxx	2020 SGD	FL# 22267.1	55	43	102	53
211	G3	156"x 120"xxx	2020 SGD	FL# 22267.1	55	43	102	53

- 1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.
- 2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

{Revised 3/14/2022}