



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM
SITE EVALUATION AND SYSTEM SPECIFICATIONS

PERMIT #. _____

APPLICANT: JORGE DE LA CONCEPCION DISNEYDI MARTINEZ AGENT: SB Engineering, Inc

LOT: 6 BLOCK: 2 SUBDIVISION: STRITTER ESTATES

PROPERTY ID #: 20-5001-053-0160 [Section/Township/Parcel No. or Tax ID Number]

TO BE COMPLETED BY ENGINEER, HEALTH DEPARTMENT EMPLOYEE, OR OTHER QUALIFIED PERSON. ENGINEERS MUST PROVIDE REGISTRATION NUMBER AND SIGN AND SEAL EACH PAGE OF SUBMITTAL. COMPLETE ALL ITEMS.

PROPERTY SIZE CONFORMS TO SITE PLAN: ☒ YES ☐ NO NET USABLE AREA AVAILABLE: 0.872 ACRES
TOTAL ESTIMATED SEWAGE FLOW: 200 GALLONS PER DAY [TABLE I / OTHER]
AUTHORIZED SEWAGE FLOW: 2180 GALLONS PER DAY [1500 GPD/ACRE OR 2500 GPD/ACRE]
UNOBSTRUCTED AREA AVAILABLE: 375 SQFT UNOBSTRUCTED AREA REQUIRED: 375 SQFT

BENCHMARK/REFERENCE POINT LOCATION: 9.35' NGVD on Curb and Gutter pripr to C/Lof SW 63rd CT
ELEVATION OF PROPOSED SYSTEM SITE IS 5.40 [INCHES/FT] [ABOVE/BELOW] BENCHMARK/REFERENCE POINT

THE MINIMUM SETBACK WHICH CAN BE MAINTAINED FROM THE PROPOSED SYSTEM TO THE FOLLOWING FEATURES
SURFACE WATER: n/a FT DITCHES/SWALES: n/a FT NORMALLY WET? ☐ YES ☒ NO
WELLS: PUBLIC: n/a FT LIMITED USE: n/a FT PRIVATE: n/a FT NON-POTABLE: n/a FT
BUILDING FOUNDATIONS: 7'-2" FT PROPERTY LINES: 21'-7" FT POTABLE WATER LINES: 5'-6" FT

SITE SUBJECT TO FREQUENT FLOODING: ☐ YES ☐ NO 10 YEAR FLOODING? ☐ YES ☐ NO
10 YEAR FLOOD ELEVATION FOR SITE: n/a FT MSL/NGVD SITE ELEVATION: 9.80 FT MSL/NGVD
SHWT = 5.80' NGVD

SOIL PROFILE INFORMATION SITE 1

MUNSELL #/COLOR	TEXTURE	DEPTH
		TO
10 YR 3/3	SAND	0" TO 7"
D.B		TO
		TO
10 YR 8/3	LIMESTONE	7" TO 7"
V.P.B	REFUSAL	TO
		TO
		TO
		TO
USDA SOIL SERIES: <u>Krome</u>		

SOIL PROFILE INFORMATION SITE 2

MUNSELL #/COLOR	TEXTURE	DEPTH
		TO
10 YR 3/3	SAND	0" TO 7"
D.B		TO
		TO
10 YR 8/3	LIMESTONE	7" TO 7"
V.P.B	REFUSAL	TO
		TO
		TO
		TO
USDA SOIL SERIES: <u>Krome</u>		

OBSERVED WATER TABLE: INCHES [ABOVE / BELOW] EXISTING GRADE. TYPE: [PERCHED / APPARENT] ESTIMATED
WET SEASON WATER TABLE ELEVATION: 48 INCHES [ABOVE / BELOW] EXISTING GRADE


HIGH WATER TABLE VEGETATION: ☐ YES ☒ NO WSWT Indicator: ☐ YES ☒ NO DEPTH: INCHES

SOIL TEXTURE/LOADING RATE FOR SYSTEM SIZING: 0.80 DEPTH OF EXCAVATION: 54 INCHES

DRAINFIELD CONFIGURATION: ☒ TRENCH ☐ BED ☐ OTHER (SPECIFY) _____

REMARKS/ADDITIONAL CRITERIA: _____

SITE EVALUATED BY: Digitally signed
by Fausto E
Guerrero
Date: 2025.05.01
15:04:34 -04'00' DATE: 04/30/2025



DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)

Incorporated: 62-6.004, FAC