

DG CONSULTING ENGINEERS, LLC

July 24, 2025

Pinecrest Building Department
Mechanical
Pinecrest, Florida

Re: 6825 SW 123rd St.
Pinecrest, FL 33156

To whom it may concern:

The following are the responses for the above referenced Mechanical permit plan reviewer comments.

Mechanical

Comment #1: Provide access panels for motorized dampers.

Response: Please see sheet M-101 Motorized damper note added.

Should you have any questions or require additional information please contact me at the address or phone number below.

Sincerely,



Daniel F. Gutierrez, P.E.
DG Consulting Engineers, LLC