VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156

PERMIT # BL2024-1025

JOB ADDRESS 12805 SW 69TH CT

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
E1	*A*	*24" X 36"*	*CSMT*	*FL20-1234*	*57.0*	*42.6*	*60.0*	*60.0*
E2	*N/A*	*4" X 2" X 96"*	*MULLION*	*20-1234.5*	*—*	*—*	*—*	*—*
122	N/A	9' x 8'	Garage Door	9209W8	Zone 5 54.1	Zone 5 40.4	62	54
					Zone 4 43.8	Zone 4 40.4		

1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.

2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)