

**Building Department:** Village of Pinecrest Building Department  
12645 Pinecrest Pkwy, Pinecrest, FL 33156  
**Project Address:** 12715 Rolling Road Drive, Miami, FL 33165  
**Process Number:** BL2026-0059

**Comments:**

1. N.O.A. FL21632.1 Documents attached are not identified in the supplement form for any openings. Please mark void all documents not applicable to this permit.

Response: The documents for N.O.A. FL21632.1 not applicable to this permit have been marked as VOID.

2. Opening 4 (FL293783.1) is shown as inswing in the floor plan sheet X-1.0. Per N.O.A. sheet #1 Figure 2 only the standard outswing sill is approved for water infiltration requirements and location must conform with the overhang ratio requirements of the F.B.C. Building Section 2411.3.2.1 Exemption 2. Provide dimensioned sections to show conformance. (All exterior swing doors in the approved master plans are outswing).


Response: Opening 4 (FL293783.1) has been updated on Floor Plan Sheet X-1.0 to indicate an outswing door, in accordance with the approved master plans. Please also refer to the note added on Sheets X-1.0 and X-3.0 regarding the required overhang ratio.

3. Identify mullion location and provide the capacity pressures on the supplement form.

Response: See attached updated supplement form indicating the mullion at mark A4. Please also refer to Sheet X-3.5 where the mullion location is shown.

If you have questions or require additional information, please do not hesitate to contact our office for further assistance.

Sincerely,



Ismael David Santana, P.E.  
Lic No. 90838

This item has been digitally signed and sealed by Ismael David Santana, P.E. on the date adjacent to the seal.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.