VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156

PERMIT # BL2024-1596

JOB ADDRESS 13125 SW 63rd Ave

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
E1	*A*	*~~24" X 36"~~*	*CSMT*	*FL20-1234*	*57.0*	*42.6*	*60.0*	*60.0*
E2	*N/A*	*~~4" X 2" X 96"~~*	*MULLION*	*20-1234.5*	*—*	*—*	*—*	*—*
S1	GL1	155" x 120"	fixed window	FL#17897	48.2	37.6	70	70
S2	GL1	237.5" x 120"	fixed window	FL#17897	48.2	37.6	70	70
S3	GL1	80" x 120"	fixed window	FL#17897	39.6	36.3	70	70
S4	GL1R	156" x 24"	fixed window	FL#17897	53.9	40.4	70	70
S5	GL1R	96" x 116"	fixed window	FL#17897	39.6	36.3	70	70
S5 Top	GL1R	156" x 14"	fixed window	FL#17897	43.8	40.4	70	70
S6	GL1	79" x 96"	fixed window	FL#17897	42.1	38.6	70	70
S7	GL1	143.5" x 120"	fixed window	FL#17897	41	37.6	70	70
S8	GL1R	88" x 120"	fixed window	FL#17897	41	37.6	70	70
S9	GL1	148" x 120"	fixed window	FL#17897	41	37.6	70	70
S10	GL1	238" x 116"	fixed window	FL#17897	48.2	37.6	70	70
S11	GL1	180" x 116"	fixed window	FL#17897	45.6	36.3	70	70
S12	GL1	81" x 116"	fixed window	FL#17897	39.6	36.3	70	70
S13	GL1R	96" x 108"	fixed window	FL#17897	41.0	37.6	70	70
S14	GL1	148" x 108"	fixed window	FL#17897	41.0	37.6	70	70
S15	GL1R	96" x 120"	fixed window	FL#17897	39.6	36.3	70	70
S16	GL1R	148" x 120"	fixed window	FL#17897	39.6	36.3	70	70

1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.

2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)