






MARK: S1
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S2
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S3
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00
DP= +70.00 PSF NOA
-70.00

THIS IS A CONDITIONAL REVIEW WITH FULL RELIANCE THAT THE CONTRACTOR HAS ATTESTED TO ITS COMPLIANCE TO THE CONTRACT DOCUMENTS AND FIELD CONDITIONS AND HAS CLEARLY MARKED 'AS NOTED' ANY AND ALL DEVIATIONS THEREOF. THE REVIEW IS PROVIDED FOR GENERAL CONFORMANCE WITH THE DESIGN INTENT AND THE CONTRACT DOCUMENTS. MARKINGS AND/OR COMMENTS ISSUED SHALL NOT BE CONSTRUED AS RELIEVING THE CONTRACTOR FROM COMPLIANCE WITH THE PROJECT PLANS AND SPECIFICATIONS, NOR DEPARTURES THERE FROM. THE CONTRACTOR REMAINS RESPONSIBLE FOR ALL DETAILS AND ACCURACY, FOR CONFIRMING AND COORDINATING ALL QUANTITIES, JOB CONDITIONS, DIMENSIONS, SELECTION OF FABRICATION PROCESSES, TECHNIQUES OF ASSEMBLY, CONSTRUCTION MEANS AND METHOD, CODE REQUIREMENTS, AND FOR PERFORMING THE WORK IN A SAFE MANNER. AFFIXING OF THE CONSULTANTS STAMP DOES NOT CONSTITUTE WAIVER OF ANY REQUIREMENT OF THE CONTRACT DOCUMENTS, UNLESS SPECIFICALLY HIGHLIGHTED BY THE REVIEWER IN WRITING. ANY DEVIATION FROM THE CONTRACT DOCUMENTS NOT PROPERLY IDENTIFIED ON THE SUBMITTAL DOCUMENTS AND BROUGHT TO THE SPECIAL ATTENTION OF THE REVIEWER, BY THE CONTRACTOR IN WRITING, IN THE SUBMITTAL, VOID THE CONSULTANT'S REVIEW AND DOCUMENT STAMPS.

MATEU ARCHITECTURE INCORPORATED
Russell A. Grover
REVIEWER
12/19/2025
DATE




MARK: S4
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
-70.00



MARK: S5 TOP
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
-70.00

MARK: S5
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
70.00



MARK: S6
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00
DP= +70.00 PSF NOA
-70.00

PROJECT:
13125 SW 63RD AVE - PRAXIS CONTRACTORS

GLASS TYPE(S)	


REV. N°	DATE	DESCRIPTION	UPDATED

CUSTOMER:
ESP WINDOWS INC.
LOCATION:
8430 NW 66 ST MIAMI, FL 33166
DRAWN BY:
L. MUÑOZ
REVIEW:
L. ROMERO


WINDOW MANUFACTURER:
ES
Imagine extraordinary
3550 NW 49th St, Miami, FL 33142, Estados Unidos
Tel. +1 754-900-2300

DESCRIPTION:
SYSTEM ELEVATIONS


DATE:
16/12/2025
SCALE:
3/16" = 1' - 0"
SHEET N°:
300
CODE: 833079




MARK: S7
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S8
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S9
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S10
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S11
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00



MARK: S12
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00
DP= +70.00 PSF NOA
-70.00



MARK: S13
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00



MARK: S14
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00

PROJECT:
13125 SW 63RD AVE - PRAXIS CONTRACTORS

GLASS TYPE(S)	


REV. N°	DATE	DESCRIPTION	UPDATED

CUSTOMER:
ESP WINDOWS INC.
LOCATION:
8430 NW 66 ST MIAMI, FL 33166
DRAFTER:
L. MUÑOZ
REVIEW:
L. ROMERO


WINDOW MANUFACTURER:
ES
Imagine extraordinary
3550 NW 49th St, Miami, FL 33142, Estados Unidos
Tel. +1 754-900-2300

DESCRIPTION:
SYSTEM ELEVATIONS


DATE:
16/12/2025
SCALE:
3/16" = 1' - 0"
SHEET N°:
301
CODE: 833079




MARK: S15
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00




MARK: S16
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S17
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S18
SYSTEM: ES-8000T WINDOW WALL
DP= +70.00 PSF FBC
-70.00




MARK: S19
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00




MARK: S20
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00



MARK: S21
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00



MARK: S22
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
-70.00



MARK: S23 OBS
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00

PROJECT:
13125 SW 63RD AVE - PRAXIS CONTRACTORS

GLASS TYPE(S)	


REV. N°	DATE	DESCRIPTION	UPDATED

CUSTOMER:
ESP WINDOWS INC.
LOCATION:
8430 NW 66 ST MIAMI, FL 33166
DRAFTER:
L. MUÑOZ
REVIEW:
L. ROMERO


WINDOW MANUFACTURER:
ES
Imagine extraordinary
3550 NW 49th St, Miami, FL 33142, Estados Unidos
Tel. +1 754-900-2300

DESCRIPTION:
SYSTEM ELEVATIONS


DATE:
16/12/2025
SCALE:
3/16" = 1' - 0"
SHEET N°:
302
CODE: 833079




MARK: S24 OBS
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
DP= -70.00




MARK: S25
SYSTEM: ES-8000T JUMBO WINDOW WALL
DP= +70.00 PSF FBC
DP= -70.00
DP= +70.00 PSF NOA
DP= -70.00




MARK: W1 XL
SYSTEM: ES-EL150 FIXED WINDOW
DP= +80.00 PSF FBC
DP= -80.00
DP= +80.00 PSF NOA
DP= -80.00




MARK: 100A
SYSTEM: ES-SGD2020 SLIDING DOOR (XX)
DP= +53.00 PSF FBC
DP= -150.00




MARK: 101
SYSTEM: ES-SGD2020 SLIDING DOOR (XX)
DP= +53.00 PSF FBC
DP= -150.00



MARK: 102
SYSTEM: ES-SGD2020 SLIDING DOOR (XXX)
DP= +53.00 PSF FBC
DP= -150.00



MARK: 114 XL
SYSTEM: ES-EL300 OUTSWING DOOR (XL)
DP= +80.00 PSF FBC
DP= -80.00
DP= +80.00 PSF NOA
DP= -80.00



MARK: 116
SYSTEM: ES-EL300 OUTSWING DOOR (XR)
DP= +80.00 PSF FBC
DP= -80.00
DP= +80.00 PSF NOA
DP= -80.00

PROJECT:
13125 SW 63RD AVE - PRAXIS CONTRACTORS

GLASS TYPE(S)	


REV. N°	DATE	DESCRIPTION	UPDATED

CUSTOMER:
ESP WINDOWS INC.
LOCATION:
8430 NW 66 ST MIAMI, FL 33166
DRAWER:
L. MUÑOZ
REVIEW:
L. ROMERO


WINDOW MANUFACTURER:
ES
Imagine extraordinary
3550 NW 49th St, Miami, FL 33142, Estados Unidos
Tel. +1 754-900-2300

DESCRIPTION:
SYSTEM ELEVATIONS


DATE:
16/12/2025
SCALE:
3/16" = 1' - 0"
SHEET N°:
303
CODE: 833079




MARK: 116A
SYSTEM:ES-SGD2020 SLIDING DOOR (XXXX)
DP= +53.00 PSF FBC
-150.00




MARK: 207
SYSTEM:ES-SGD2020 SLIDING DOOR (XXX)
DP= +53.00 PSF FBC
-102.00



MARK: 216A
SYSTEM:ES-SGD2020 SLIDING DOOR (XXX)




MARK: 216B
SYSTEM:ES-SGD2020 SLIDING DOOR (XX)
DP= +53.00 PSF FBC
-150.00




MARK: 219 SF
SYSTEM: ES-8000T WINDOW WALL
DP= +60.00 PSF FBC
-70.00

MARK: 219 DOOR
SYSTEM: SYSTEM: ES-EL300 OUTSWING DOOR (XL)
DP= +80.00 PSF FBC
-80.00
DP= +80.00 PSF NOA
-80.00



MARK: 109
SYSTEM: ES-EL300 OUTSWING DOOR (XL)
DP= +80.00 PSF FBC
-80.00
DP= +80.00 PSF NOA
-80.00



MARK: 215
SYSTEM: ES-EL300 OUTSWING DOOR (XR)
DP= +80.00 PSF FBC
-80.00
DP= +80.00 PSF NOA
-80.00

PROJECT: 13125 SW 63RD AVE - PRAXIS CONTRACTORS	GLASS TYPE(S)		REV. N°	DATE	DESCRIPTION	UPDATED	CUSTOMER: ESP WINDOWS INC. LOCATION: 8430 NW 66 ST MIAMI, FL 33166 DRAFTER: L. MUÑOZ REVIEW: L. ROMERO	WINDOW MANUFACTURER:  3550 NW 49th St, Miami, FL 33142, Estados Unidos Tel. +1 754-900-2300	DESCRIPTION: SYSTEM ELEVATIONS	DATE: 16/12/2025 SCALE: 3/16" = 1' - 0" SHEET N°: 304 CODE: 833079