


STRUCTURAL CALCULATIONS

FOR

ALUMINUM CABLE RAILING SHOP DRAWINGS

9601SW 67th AVENUE-PINECREST,
FL 33156

To the best of my knowledge and professional judgement all calculations contained herein have been reviewed, and conform to the recommendation of ASCE/SEI 7-22, ACI 318-19, AISC 360-16, and the 2023 Florida Building Code, 8th Edition



BRC CONSULTANTS

7211 W 24 AVE, HIALEAH , FL 33016

Project Name:	ALUMINUM CABLE RAILING	
Project No.:		Sheet No.:
Calculated By:		Date:
Checked By:		Date:

INDEX

1.	ALUMINUM CABLE RAILING DESIGN.....	PAGES: 01-26
2.	SECTIONS PROPERTIES.....	PAGES: 27-28

Horizontal Cable Railing Design (Top, Bottom, Anchor Post, Intermediate Post)

H=28 in

DESIGN INFORMATION:

DESIGN LOADS:


Handrail Design Loads: Concentrated Load = 200 lbs. applied at any point in any direction.

Uniform Load = 50 plf applied in any direction (other than dwelling units).

Guardrail System Loads: Concentrated Load = 200 lbs. applied at any point in any direction at the top of the guardrail (other than dwelling units include a load of 100 lbs applied vertically downward at the top of guardrail).

Concentrated horizontal load of 200 lbs applied on a 1 sq ft. area at any point in the system.

Handrail Design:



ALUMINUM POST ALLOWABLE STRESSES

2"x2"x1/4"

$$B := 2 \text{ in}$$

$$t := 0.25 = 0.250 \text{ in}$$

$$b := B - 2t = 1.50$$

$$\frac{b}{t} = 6.00 \quad \lambda_1 := 6.7 \quad \lambda_2 := 10.5 \quad \frac{b}{t} < \lambda_1$$

SO

$$F_{b_{PT,I}} := 21200 = 21200.00$$

psi

$$F_{v_{PT,I}} := 12700$$

psi

ALUMINUM TOP RAIL ALLOWABLE STRESSES

2"x1.5"x1/8"

$$B := 1.5 \text{ in}$$

$$t := 0.125 = 0.125 \text{ in}$$

$$b := B - 2t = 1.25$$

$$\frac{b}{t} = 10.00 \quad \lambda_1 := 20.8 \quad \lambda_2 := 33 \quad \frac{b}{t} < \lambda_1$$

SO

$$F_{b_{TR}} := 21200 = 21200.00$$

psi

$$F_{v_{TR}} := 12700$$

psi

General Data:

$L_r := 38.5$ Railing Span (in)

$H_{post} := 28$ Post Height (in)

General Loads:

$q_{wind} := 10.00$ Wind Pressure (psf)

$P_{200} := 200.00$ Single Concentrated Load (lbs)Railing P=200.00, Fence P=0.00

$q_{50} := 50.00$ Uniform Distributed Load (plf).....Railing q=50.00, Fence q=0.00

Top Railing Data:

2x1.5x1/8

$F_{bTR} = 21200.00$ psi

$F_{VTR} = 12700.00$ psi

$S_{XTR} := 0.37$ For Vertical Loads (in^3)

$S_{YTR} := 0.442$ For Horizontal Loads (in^3)

$A_{TR} := 0.813$ in^2

Cable Data:

$F_{ycable} := 50000.00$ psi

$\phi_{cable} := 0.1875$ in

$E_{cable} := 16345000.00$ psi

Post Anchor Data:

2X2X1/4

$F_{bPT} := 21200$ psi

$F_{VPT} := 12700$ psi

$S_{XPT} := 0.911$ For Railings Loads (in^3)

$S_{YPT} := 0.911$ For Cable Loads (in^3)

$A_{PT} := 1.75$ in^2

Post Intermediate Data:

2X2X1/4

$F_{bPT.I} = 21200.00$ psi

$F_{VPT.I} = 12700.00$ psi

$S_{XPT.I} := 0.911$ For Railings Loads (in^3)

$A_{PT.I} := 1.75$ in^2

Cable Design:

$L_{cable} := 38.5$ Maximum Cable Intermediate Post Span (in)

$s_{cable} := 3$ Cable spacing O.C.(in)

$L_T := 154$ Length of cable between anchor points (in)

$F_{ps} := 220$ Applied prestressing Force (lbs)

For Sphere Pass-Through Resistance with
w=50 psf through 2 cables & Vertical Maximum Deflection Plus Impact Factor=2

$$A_{\text{cable}} := \pi \cdot \frac{\phi_{\text{cable}}^2}{4}$$

$$A_{\text{cable}} = 0.03 \text{ in}^2$$

$$I_{\text{cable}} := 0.70 \left(\pi \cdot \frac{\phi_{\text{cable}}^4}{64} \right)$$

$$I_{\text{cable}} = 0.0000 \text{ in}^4$$

$$\Delta_V := \begin{cases} x \leftarrow 0.01 \\ \text{while } \frac{4 \cdot x \cdot E_{\text{cable}} \cdot A_{\text{cable}}}{L_{\text{cable}}} \cdot \frac{\sqrt{4 \cdot x^2 + L_{\text{cable}}^2} - L_{\text{cable}}}{\sqrt{4 \cdot x^2 + L_{\text{cable}}^2} + L_T - L_{\text{cable}}} + \frac{48 \cdot E_{\text{cable}} \cdot I_{\text{cable}} \cdot x}{L_{\text{cable}}^3} + \frac{4 \cdot F_{\text{ps}} \cdot x}{L_{\text{cable}}} \leq \frac{2 \cdot \left(50 \cdot \frac{\pi \cdot 4^2}{4 \cdot 144} \right)}{2 \cdot \cos \left(\text{asin} \left(\frac{s_{\text{cable}} + 2 \cdot x}{4 + \phi_{\text{cable}}} \right) \right)} \\ x \leftarrow x + 0.001 \end{cases}$$

$$\Delta_V = 0.40 \text{ in}$$

$$P_{\text{ef}} := \frac{2 \left(50 \cdot \frac{\pi \cdot 4^2}{4 \cdot 144} \right)}{2 \cos \left(\text{asin} \left(\frac{s_{\text{cable}} + 2 \cdot \Delta_V}{4 + \phi_{\text{cable}}} \right) \right)}$$

$$P_{\text{ef}} = 10.39 \text{ lbs}$$

$$T_{\text{cable}} := \frac{P_{\text{ef}}}{2 \cdot \Delta_V} \cdot \sqrt{\Delta_V^2 + \frac{L_{\text{cable}}^2}{4}}$$

$$T_{\text{cable}} = 249.96 \text{ lbs}$$

Cable Section Required:

$$\phi_{\text{cable.req}} := \sqrt{4 \cdot \frac{\frac{T_{\text{cable}}}{0.9 \cdot F_{\text{ycable}}}}{\pi}}$$

$$\phi_{\text{cable.req}} = 0.08 \text{ in}$$

Section Provided:

$$\text{TENSION}_{\text{cable}} := \text{if}(\phi_{\text{cable}} \geq \phi_{\text{cable.req}}, \text{"O.K."}, \text{"N.G."})$$

$$\text{TENSION}_{\text{cable}} = \text{"O.K."}$$

Top Railing Vertical Design:

Maximum Moment for Vertical Loads:

Concentrated Load = 200 lbs

$$M_{\text{TR.200.V}} := \frac{P_{200} \cdot L}{5}$$

$$M_{\text{TR.200.V}} = 1540.00 \text{ in} - \text{lb}$$

Uniform Load = 50 plf

$$M_{TR.50.V} := 0.1012 \cdot \left(\frac{q_{50}}{12} \right) \cdot L^2$$

$$M_{TR.50.V} = 625.02 \quad \text{in} - \text{lb}$$

$$M_{TR.V} := \max(M_{TR.50.V}, M_{TR.200.V})$$

$$M_{TR.V} = 1540.00 \quad \text{in} - \text{lb}$$

Maximum Shear for Vertical Loads:

Concentrated Load = 200 lbs.

$$V_{TR.200} := P_{200}$$

$$V_{TR.200} = 200.00 \quad \text{lbs}$$

Uniform Load = 50 plf.

$$V_{TR.50} := 0.6 \cdot \left(\frac{q_{50}}{12} \cdot L \right)$$

$$V_{TR.50} = 96.25 \quad \text{lbs}$$

$$V_{TR.V} := \max(V_{TR.200}, V_{TR.50})$$

$$V_{TR.V} = 200.00 \quad \text{lbs}$$

Maximum Axial for Cable Loads:

$$P_{TR.V} := \frac{T_{\text{cable}} \cdot \text{floor} \left(\frac{H_{\text{post}}}{S_{\text{cable}}} \right)}{2}$$

$$P_{TR.V} = 1124.81 \quad \text{lbs.}$$

***See Attached Axial and Bending Combined Calculations for Top Railing Vertical Loads

Top Railing Horizontal Design:

Maximum Moment for Horizontal Loads:

Concentrated Load = 200 lbs

$$M_{TR.200.H} := \frac{P_{200} \cdot L}{5}$$

$$M_{TR.200.H} = 1540.00 \quad \text{in} - \text{lb}$$

Uniform Load = 50 plf

$$M_{TR.50.H} := 0.1012 \cdot \left(\frac{q_{50}}{12} \right) \cdot L^2$$

$$M_{TR.50.H} = 625.02 \quad \text{in} - \text{lb}$$

For Wind Pressure

$$M_{TR.\text{wind}} := 0.1012 \cdot \left(\frac{q_{\text{wind}}}{144} \right) \cdot \left(\frac{H_{\text{post}}}{2} \cdot L^2 \right)$$

$$M_{TR.\text{wind}} = 145.84 \quad \text{in} - \text{lb}$$

$$M_{TR.H} := \max(M_{TR.200.H}, M_{TR.50.H}, M_{TR.\text{wind}})$$

$$M_{TR.H} = 1540.00 \quad \text{in} - \text{lb}$$

Maximum Shear for Horizontal Loads:

Concentrated Load = 200 lbs.

$$V_{TR.200.H} := P_{200}$$

$$V_{TR.200.H} = 200.00 \text{ lbs}$$

Uniform Load = 50 plf

$$V_{TR.50.H} := 0.6 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$V_{TR.50.H} = 96.25 \text{ lbs}$$

For Wind Pressure

$$V_{TR.wind} := 0.6 \cdot \left(\frac{q_{wind}}{144} \right) \cdot \left(\frac{H_{post}}{2} \right) \cdot L$$

$$V_{TR.wind} = 22.46 \text{ lbs}$$

$$V_{TR.H} := \max(V_{TR.200.H}, V_{TR.50.H}, V_{TR.wind})$$

$$V_{TR.H} = 200.00 \text{ lbs}$$

Maximum Axial for Cable Loads:

$$P_{TR.H} := \frac{T_{cable} \cdot \text{floor} \left(\frac{H_{post}}{s_{cable}} \right)}{2}$$

$$P_{TR.H} = 1124.81 \text{ lbs.}$$

***See Attached Axial and Bending Combined Calculations for Top Railing Horizontal Loads

Post Intermediate Design:

Maximum Reactions:

Concentrated Load = 200 lbs.

$$R_{PTI.200} := P_{200}$$

$$R_{PTI.200} = 200.00 \text{ lbs}$$

Uniform Load = 50 plf

$$R_{PTI.50} := 1.0 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$R_{PTI.50} = 160.42 \text{ lbs}$$

For Wind Pressure

$$R_{PTI.wind} := 1.0 \cdot \left(\frac{q_{wind}}{144} \right) \cdot H_{post} \cdot L$$

$$R_{PTI.wind} = 74.86 \text{ lbs}$$

$$R_{PTI} := \max(R_{PTI.200}, R_{PTI.50}, R_{PTI.wind})$$

$$R_{PTI} = 200.00 \text{ lbs}$$

Maximum Moment:

$$M_{PTI} := R_{PTI} \cdot H_{post}$$

$$M_{PTI} = 5600.00 \text{ in - lb}$$

Maximum Shear:

$$V_{PTI} := R_{PTI}$$

$$V_{PTI} = 200.00 \quad \text{lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PTL.xx} := \frac{M_{PTI}}{F_{b_{PT.I}}}$$

$$S_{PTL.xx} = 0.26 \quad \text{in}^3$$

Shear Design: Area Required:

$$A_{PTL.xx} := \frac{1.5 \cdot V_{PTI}}{F_{v_{PT.I}}}$$

$$A_{PTL.xx} = 0.02 \quad \text{in}^2$$

Post Intermediate Section Provided:

$$BENDING_{PT.I} := \text{if}(S_{PTL.xx} \geq S_{X_{PT.I}}, "N.G", "OK")$$

$$BENDING_{PT.I} = "OK"$$

$$SHEAR_{PT.I} := \text{if}(A_{PTL.xx} \geq A_{PT.I}, "N.G", "OK")$$

$$SHEAR_{PT.I} = "OK"$$

Post Anchor Along X-X Axis Design:

Maximum Reactions:

Concentrated Load = 200 lbs.

$$R_{PT.200} := P_{200}$$

$$R_{PT.200} = 200.00 \quad \text{lbs}$$

Uniform Load = 50 plf

$$R_{PT.50} := 1.0 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$R_{PT.50} = 160.42 \quad \text{lbs}$$

For Wind Pressure

$$R_{PT.wind} := 1.0 \cdot \left(\frac{q_{wind}}{144} \right) \cdot H_{post} \cdot L$$

$$R_{PT.wind} = 74.86 \quad \text{lbs}$$

$$R_{PT.xx} := \max(R_{PT.200}, R_{PT.50}, R_{PT.wind})$$

$$R_{PT.xx} = 200.00 \quad \text{lbs}$$

Maximum Moment:

$$M_{PT.xx} := R_{PT.xx} \cdot H_{post}$$

$$M_{PT.xx} = 5600.00 \quad \text{in - lb}$$

Maximum Shear:

$$V_{PT.xx} := R_{PT.xx}$$

$$V_{PT.xx} = 200.00 \quad \text{lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PT.xx} := \frac{M_{PT.xx}}{Fb_{PT}} \quad S_{PT.xx} = 0.26 \text{ in}^3$$

Shear Design: Area Required:

$$A_{PT.xx} := \frac{1.5 \cdot V_{PT.xx}}{Fv_{PT}} \quad A_{PT.xx} = 0.02 \text{ in}^2$$

Post Anchor Section Provided:

$$BENDING_{PT.xx} := \text{if}(S_{PT.xx} \geq S_{xPT}, \text{"N.G"}, \text{"OK"}) \quad BENDING_{PT.xx} = \text{"OK"}$$

$$SHEAR_{PT.xx} := \text{if}(A_{PT.xx} \geq A_{PT}, \text{"N.G"}, \text{"OK"}) \quad SHEAR_{PT.xx} = \text{"OK"}$$

Post Anchor Along Y-Y Axis Design (Cable Tension):

Maximum Moment:

$$M_{PT.yy} := \frac{T_{cable} \cdot \text{floor} \left(\frac{H_{post}}{s_{cable}} \right) \cdot H_{post}}{8} \quad M_{PT.yy} = 7873.65 \text{ in} - \text{lb}$$

Maximum Shear:

$$V_{post_{max.yy}} := \frac{T_{cable} \cdot \text{floor} \left(\frac{H_{post}}{s_{cable}} \right)}{2} \quad V_{post_{max.yy}} = 1124.81 \text{ lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PT.yy} := \frac{M_{PT.yy}}{Fb_{PT}} \quad S_{PT.yy} = 0.37 \text{ in}^3$$

Shear Design (Area Required)

$$A_{PT.yy} := \frac{1.5 \cdot V_{post_{max.yy}}}{Fv_{PT}} \quad A_{PT.yy} = 0.13 \text{ in}^2$$

Post Anchor Section Provided:

$$BENDING_{PT.yy} := \text{if}(S_{PT.yy} \geq S_{yPT}, \text{"N.G"}, \text{"OK"}) \quad BENDING_{PT.yy} = \text{"OK"}$$

$$SHEAR_{PT.yy} := \text{if}(A_{PT.yy} \geq A_{PT}, \text{"N.G"}, \text{"OK"}) \quad SHEAR_{PT.yy} = \text{"OK"}$$

Post Anchor Combined Stress (Bending at Hpost/2)

$$fb_{PT.xx.0.5H} := \frac{M_{PT.xx}}{2S_{xPT}}$$

$$fb_{PT.xx.0.5H} = 3073.55 \text{ psi}$$

$$fb_{PT.yy} := \frac{M_{PT.yy}}{S_{yPT}}$$

$$fb_{PT.yy} = 8642.86 \text{ psi}$$


$$IE_{PT} := \frac{fb_{PT.xx.0.5H}}{Fb_{PT}} + \frac{fb_{PT.yy}}{Fb_{PT}}$$

$$IE_{PT} = 0.55$$

$$COMBINED_{PT} := \begin{cases} \text{"N.G."} \\ \text{"OK"} & \text{if } 1 \geq IE_{PT} \end{cases}$$

$$COMBINED_{PT} = \text{"OK"}$$

Post Anchorage to Concrete:



Post Data:

$$B_{post} := 2$$

Post Width (in)

$$D_{post} := 2$$

Post Depth (in)

$$h_{ef} := 4.5$$

Post Embedment (in)

$$C_{a1} := 6$$

Minimum Edge Distance (in)

Grout Size Data:

$$B_{\text{grout}} := 4 \quad \text{Equivalent Grout Width (in)}$$

$$D_{\text{grout}} := 4 \quad \text{Equivalent Grout Depth (in)}$$

$$f_{c_{\text{grout}}} := 10000.00 \quad \text{Grout Strength (psi)}$$

Concrete Slab Data:

$$f_{c_{\text{concrete}}} := 4000 \quad \text{Concrete Strength (psi)}$$

$$d_o := 4 \quad \text{Hold diameter (Grout Diameter) (in)}$$

$$h_a := 12 \quad \text{Concrete Slab Deep (in)}$$

Equivalent Maximum Horizontal Load at Top Railing Height (Pd)

$$Pd := R_{PT.xx} \quad Pd = 200.00 \quad \text{lbs}$$

Arm Effect:

$$a := \frac{2 \cdot h_{ef}^2 + 3 \cdot H_{post} \cdot h_{ef}}{3 \cdot h_{ef} + 6 \cdot H_{post}} \quad a = 2.31 \quad \text{in}$$

$$P_2 := \frac{Pd \cdot a^2}{h_{ef} \cdot (2 \cdot a - h_{ef})} \quad P_2 = 2117.91 \quad \text{lbs}$$

$$P_1 := P_2 - Pd \quad P_1 = 1917.91 \quad \text{lbs}$$

$$M_{\text{external}} := Pd \cdot (H_{post} + a) \quad M_{\text{external}} = 6061.16 \quad \text{lbs} - \text{in}$$

$$M_{\text{internal}} := P_2 \cdot \frac{2}{3} \cdot a + P_1 \cdot \frac{2}{3} \cdot (h_{ef} - a) \quad M_{\text{internal}} = 6061.16 \quad \text{lbs} - \text{in}$$

$$Vu := 1.6 \cdot (\max(P_1, P_2)) \quad Vu = 3388.65 \quad \text{lbs}$$

Stress Analysis Between Post and Grout:

$$f_{2,\text{grout}} := 1.6 \cdot \frac{2 \cdot P_2}{a \cdot B_{\text{post}}}$$

$$f_{2,\text{grout}} = 1469.63 \quad \text{psi}$$

$$f_{1,\text{grout}} := 1.6 \cdot \frac{2 \cdot P_1}{(h_{\text{ef}} - a) \cdot B_{\text{post}}}$$

$$f_{1,\text{grout}} = 1398.52 \quad \text{psi}$$

Bearing Stress for Grout :

$$F_{p\text{grout}} := [0.65 \cdot (0.85 f_{c\text{grout}})] \cdot 1.5$$

$$F_{p\text{grout}} = 8287.50 \quad \text{psi}$$

$$\text{Stress}_{\text{grout}} := \begin{cases} \text{"N.G."} \\ \text{"O.K."} & \text{if } \max(f_{1,\text{grout}}, f_{2,\text{grout}}) \leq F_{p\text{grout}} \end{cases}$$

$$\text{Stress}_{\text{grout}} = \text{"O.K."}$$

Stress Analysis Between Grout and Concrete:

$$f_{2,\text{concrete}} := 1.6 \cdot \frac{2 \cdot P_2}{a \cdot B_{\text{grout}}}$$

$$f_{2,\text{concrete}} = 734.81 \quad \text{psi}$$

$$f_{1,\text{concrete}} := 1.6 \cdot \frac{2 \cdot P_1}{(h_{\text{ef}} - a) \cdot B_{\text{grout}}}$$

$$f_{1,\text{concrete}} = 699.26 \quad \text{psi}$$

Bearing Stress for Concrete :

$$F_{p\text{concrete}} := [0.65 \cdot (0.85 \cdot f_{c\text{concrete}})] \cdot 1.5$$

$$F_{p\text{concrete}} = 3315.00 \quad \text{psi}$$

$$\text{Stress}_{\text{concrete}} := \begin{cases} \text{"N.G."} \\ \text{"O.K."} & \text{if } \max(f_{1,\text{concrete}}, f_{2,\text{concrete}}) \leq F_{p\text{concrete}} \end{cases}$$

$$\text{Stress}_{\text{concrete}} = \text{"O.K."}$$

Shear Analysis-Concrete Breakout Strength:

$$A_{V\text{co}} := 4.5 \cdot C_{a1}^2$$

$$A_{V\text{co}} = 162 \quad \text{in}^2$$

$$A_{Vc} := \begin{cases} 2 \cdot (1.5 \cdot C_{a1}) \cdot h_a & \text{if } h_a < 1.5 \cdot C_{a1} \\ 2 \cdot (1.5 \cdot C_{a1}) \cdot (1.5 \cdot C_{a1}) & \text{if } h_a \geq 1.5 \cdot C_{a1} \end{cases}$$

$$A_{Vc} = 162.00 \quad \text{in}^2$$

$$\psi_{ed,V} := 1.00 \quad \text{Modification factor for edge effect}$$

$$\psi_{c,V} := 1 \quad \text{Modification Factor in No cracked concrete at service loads}$$

$\psi_{c,V}=1.4$
 Modification Factor in cracked concrete with
 $\psi_{c,V}=1$ w/ No supplementary reinforcement.
 $\psi_{c,V}=1.2$ w/ Supplementary reinforcement of a No 4 Bar between the anchor and the edge.
 $\psi_{c,V}=1.4$ w/ Supplementary reinforcement of No 4 Bar and stirrups spaced at not more than 4 in

$$l_e := \text{if}(h_{ef} > 8 \cdot d_o, 8 \cdot d_o, h_{ef}) \quad l_e = 4.50 \text{ in}$$

$$V_b := 7 \cdot \left[\left(\frac{l_e}{d_o} \right)^{0.2} \sqrt{d_o} \cdot \sqrt{f_{c,concrete}} \cdot C_{al}^{1.5} \right] \quad V_b = 13323.41 \text{ lbs.}$$

$$V_{cb} := \frac{A_{Vc}}{A_{Vco}} \cdot \psi_{ed,V} \cdot \psi_{c,V} \cdot V_b \quad V_{cb} = 13323.41 \text{ lbs.}$$

$$\phi := 0.7 \quad \text{Conditions}$$

$\phi=0.75$ w/ Supplementary reinforcement are crossing concrete failure prism.
 $\phi=0.70$ w/ No supplementary reinforcement are crossing concrete failure prism.

$$\phi \cdot V_{cb} = 9326.39 \text{ lbs}$$

$$\text{BREAKOUT}_{\text{shear}} := \text{if}(V_u > \phi \cdot V_{cb}, \text{"N.G."}, \text{"OK"}) \quad \text{BREAKOUT}_{\text{shear}} = \text{"OK"}$$

Shear Analysis-Concrete Burst-Out Strength:

$$C_{a1c} := \begin{cases} C_{a1} \\ \text{"N/A"} & \text{if } h_a < C_{a1} \end{cases} \quad C_{a1c} = 6.00 \text{ in}$$

Total Cone Area for Failure Plane

$$A_{\text{cone},\text{total}} := \sqrt{2} \cdot C_{a1c} \cdot \pi \cdot \left(C_{a1c} - \frac{D_{\text{grout}}}{2} + \frac{B_{\text{grout}}}{2} \right) \quad A_{\text{cone},\text{total}} = 159.94 \text{ in}^2$$

Cone Area for Failure Plane at Post

$$A_{\text{cone},\text{post}} := \sqrt{2} \cdot \left(\frac{B_{\text{grout}}}{2} \right)^2 \cdot \pi \quad A_{\text{cone},\text{post}} = 17.77 \text{ in}^2$$

Final Cone Area for Failure Plane

$$A_{\text{cone.final}} := \frac{A_{\text{cone.total}} - A_{\text{cone.post}}}{2}$$

$$A_{\text{cone.final}} = 71.09 \text{ in}^2$$

Final Area for Failure Plane

$$V_{\text{cone.cb}} := 4 \cdot \sqrt{f_{\text{concrete}}} \cdot A_{\text{cone.final}}$$

$$V_{\text{cone.cb}} = 17983.53 \text{ lbs}$$

$$\phi_{\text{B.O}} := 0.75$$

Conditions
 $\phi=0.75$ for Any Condition

$$\phi_{\text{B.O}} \cdot V_{\text{cone.cb}} = 13487.64 \text{ lbs}$$

$$\text{BURSTOUT}_{\text{shear}} := \text{if}(V_u > \phi_{\text{B.O}} \cdot V_{\text{cone.cb}}, \text{"N.G."}, \text{"OK"})$$

$$\text{BURSTOUT}_{\text{shear}} = \text{"OK"}$$

Horizontal Cable Railing Design (Top, Bottom, Anchor Post, Intermediate Post)

H=26 in

DESIGN INFORMATION:

DESIGN LOADS:


Handrail Design Loads: Concentrated Load = 200 lbs. applied at any point in any direction.

Uniform Load = 50 plf applied in any direction (other than dwelling units).

Guardrail System Loads: Concentrated Load = 200 lbs. applied at any point in any direction at the top of the guardrail (other than dwelling units include a load of 100 lbs applied vertically downward at the top of guardrail).

Concentrated horizontal load of 200 lbs applied on a 1 sq ft. area at any point in the system.

Handrail Design:



ALUMINUM POST ALLOWABLE STRESSES

2"x2"x1/4"

$$B := 2 \text{ in}$$

$$t := 0.25 = 0.250 \text{ in}$$

$$b := B - 2t = 1.50$$

$$\frac{b}{t} = 6.00 \quad \lambda_1 := 6.7 \quad \lambda_2 := 10.5 \quad \frac{b}{t} < \lambda_1$$

SO

$$F_{b_{PT,I}} := 21200 = 21200.00$$

psi

$$F_{v_{PT,I}} := 12700$$

psi

ALUMINUM TOP RAIL ALLOWABLE STRESSES

2"x1.5"x1/8"

$$B := 1.5 \text{ in}$$

$$t := 0.125 = 0.125 \text{ in}$$

$$b := B - 2t = 1.25$$

$$\frac{b}{t} = 10.00 \quad \lambda_1 := 20.8 \quad \lambda_2 := 33 \quad \frac{b}{t} < \lambda_1$$

SO

$$F_{b_{TR}} := 21200 = 21200.00$$

psi

$$F_{v_{TR}} := 12700$$

psi

General Data:

$L_r := 47$ Railing Span (in)

$H_{post} := 26$ Post Height (in)

General Loads:

$q_{wind} := 10.00$ Wind Pressure (psf)

$P_{200} := 200.00$ Single Concentrated Load (lbs)Railing P=200.00, Fence P=0.00

$q_{50} := 50.00$ Uniform Distributed Load (plf).....Railing q=50.00, Fence q=0.00

Top Railing Data:

2x1.5x1/8

$Fb_{TR} = 21200.00$ psi

$Fv_{TR} = 12700.00$ psi

$Sx_{TR} := 0.37$ For Vertical Loads (in^3)

$Sy_{TR} := 0.442$ For Horizontal Loads (in^3)

$A_{TR} := 0.813$ in^2

Cable Data:

$Fy_{cable} := 50000.00$ psi

$\phi_{cable} := 0.1875$ in

$E_{cable} := 16345000.00$ psi

Post Anchor Data:

2X2X1/4

$Fb_{PT} := 21200$ psi

$Fv_{PT} := 12700$ psi

$Sx_{PT} := 0.911$ For Railings Loads (in^3)

$Sy_{PT} := 0.911$ For Cable Loads (in^3)

$A_{PT} := 1.75$ in^2

Post Intermediate Data:

2X2X1/4

$Fb_{PT.I} = 21200.00$ psi

$Fv_{PT.I} = 12700.00$ psi

$Sx_{PT.I} := 0.911$ For Railings Loads (in^3)

$A_{PT.I} := 1.75$ in^2

Cable Design:

$L_{cable} := 47$ Maximum Cable Intermediate Post Span (in)

$s_{cable} := 3$ Cable spacing O.C.(in)

$L_T := 140$ Length of cable between anchor points (in)

$F_{ps} := 280$ Applied prestressing Force (lbs)

For Sphere Pass-Through Resistance with
w=50 psf through 2 cables & Vertical Maximum Deflection Plus Impact Factor=2

$$A_{\text{cable}} := \pi \cdot \frac{\phi_{\text{cable}}^2}{4}$$

$$A_{\text{cable}} = 0.03 \text{ in}^2$$

$$I_{\text{cable}} := 0.70 \left(\pi \cdot \frac{\phi_{\text{cable}}^4}{64} \right)$$

$$I_{\text{cable}} = 0.0000 \text{ in}^4$$

$$\Delta_V := \begin{cases} x \leftarrow 0.01 \\ \text{while } \frac{4 \cdot x \cdot E_{\text{cable}} \cdot A_{\text{cable}}}{L_{\text{cable}}} \cdot \frac{\sqrt{4 \cdot x^2 + L_{\text{cable}}^2} - L_{\text{cable}}}{\sqrt{4 \cdot x^2 + L_{\text{cable}}^2} + L_T - L_{\text{cable}}} + \frac{48 \cdot E_{\text{cable}} \cdot I_{\text{cable}} \cdot x}{L_{\text{cable}}^3} + \frac{4 \cdot F_{\text{ps}} \cdot x}{L_{\text{cable}}} \leq \frac{2 \cdot \left(50 \cdot \frac{\pi \cdot 4^2}{4 \cdot 144} \right)}{2 \cdot \cos \left(\text{asin} \left(\frac{s_{\text{cable}} + 2 \cdot x}{4 + \phi_{\text{cable}}} \right) \right)} \\ x \leftarrow x + 0.001 \end{cases}$$

$$\Delta_V = 0.40 \text{ in}$$

$$P_{\text{ef}} := \frac{2 \left(50 \cdot \frac{\pi \cdot 4^2}{4 \cdot 144} \right)}{2 \cos \left(\text{asin} \left(\frac{s_{\text{cable}} + 2 \cdot \Delta_V}{4 + \phi_{\text{cable}}} \right) \right)}$$

$$P_{\text{ef}} = 10.29 \text{ lbs}$$

$$T_{\text{cable}} := \frac{P_{\text{ef}}}{2 \cdot \Delta_V} \cdot \sqrt{\Delta_V^2 + \frac{L_{\text{cable}}^2}{4}}$$

$$T_{\text{cable}} = 305.22 \text{ lbs}$$

Cable Section Required:

$$\phi_{\text{cable.req}} := \sqrt{4 \cdot \frac{\frac{T_{\text{cable}}}{0.9 \cdot F_{\text{ycable}}}}{\pi}}$$

$$\phi_{\text{cable.req}} = 0.09 \text{ in}$$

Section Provided:

$$\text{TENSION}_{\text{cable}} := \text{if}(\phi_{\text{cable}} \geq \phi_{\text{cable.req}}, \text{"O.K."}, \text{"N.G."})$$

$$\text{TENSION}_{\text{cable}} = \text{"O.K."}$$

Top Railing Vertical Design:

Maximum Moment for Vertical Loads:

Concentrated Load = 200 lbs

$$M_{\text{TR.200.V}} := \frac{P_{200} \cdot L}{5}$$

$$M_{\text{TR.200.V}} = 1880.00 \text{ in} - \text{lb}$$

Uniform Load = 50 plf

$$M_{TR.50.V} := 0.1012 \cdot \left(\frac{q_{50}}{12} \right) \cdot L^2$$

$$M_{TR.50.V} = 931.46 \quad \text{in} - \text{lb}$$

$$M_{TR.V} := \max(M_{TR.50.V}, M_{TR.200.V})$$

$$M_{TR.V} = 1880.00 \quad \text{in} - \text{lb}$$

Maximum Shear for Vertical Loads:

Concentrated Load = 200 lbs.

$$V_{TR.200} := P_{200}$$

$$V_{TR.200} = 200.00 \quad \text{lbs}$$

Uniform Load = 50 plf.

$$V_{TR.50} := 0.6 \cdot \left(\frac{q_{50}}{12} \cdot L \right)$$

$$V_{TR.50} = 117.50 \quad \text{lbs}$$

$$V_{TR.V} := \max(V_{TR.200}, V_{TR.50})$$

$$V_{TR.V} = 200.00 \quad \text{lbs}$$

Maximum Axial for Cable Loads:

$$P_{TR.V} := \frac{T_{\text{cable}} \cdot \text{floor} \left(\frac{H_{\text{post}}}{S_{\text{cable}}} \right)}{2}$$

$$P_{TR.V} = 1220.89 \quad \text{lbs.}$$

***See Attached Axial and Bending Combined Calculations for Top Railing Vertical Loads

Top Railing Horizontal Design:

Maximum Moment for Horizontal Loads:

Concentrated Load = 200 lbs

$$M_{TR.200.H} := \frac{P_{200} \cdot L}{5}$$

$$M_{TR.200.H} = 1880.00 \quad \text{in} - \text{lb}$$

Uniform Load = 50 plf

$$M_{TR.50.H} := 0.1012 \cdot \left(\frac{q_{50}}{12} \right) \cdot L^2$$

$$M_{TR.50.H} = 931.46 \quad \text{in} - \text{lb}$$

For Wind Pressure

$$M_{TR.wind} := 0.1012 \cdot \left(\frac{q_{wind}}{144} \right) \cdot \left(\frac{H_{post}}{2} \cdot L^2 \right)$$

$$M_{TR.wind} = 201.82 \quad \text{in} - \text{lb}$$

$$M_{TR.H} := \max(M_{TR.200.H}, M_{TR.50.H}, M_{TR.wind})$$

$$M_{TR.H} = 1880.00 \quad \text{in} - \text{lb}$$

Maximum Shear for Horizontal Loads:

Concentrated Load = 200 lbs.

$$V_{TR.200.H} := P_{200}$$

$$V_{TR.200.H} = 200.00 \text{ lbs}$$

Uniform Load = 50 plf

$$V_{TR.50.H} := 0.6 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$V_{TR.50.H} = 117.5 \text{ lbs}$$

For Wind Pressure

$$V_{TR.wind} := 0.6 \cdot \left(\frac{q_{wind}}{144} \right) \cdot \left(\frac{H_{post}}{2} \right) \cdot L$$

$$V_{TR.wind} = 25.46 \text{ lbs}$$

$$V_{TR.H} := \max(V_{TR.200.H}, V_{TR.50.H}, V_{TR.wind})$$

$$V_{TR.H} = 200.00 \text{ lbs}$$

Maximum Axial for Cable Loads:

$$P_{TR.H} := \frac{T_{cable} \cdot \text{floor} \left(\frac{H_{post}}{s_{cable}} \right)}{2}$$

$$P_{TR.H} = 1220.89 \text{ lbs.}$$

***See Attached Axial and Bending Combined Calculations for Top Railing Horizontal Loads

Post Intermediate Design:

Maximum Reactions:

Concentrated Load = 200 lbs.

$$R_{PTI.200} := P_{200}$$

$$R_{PTI.200} = 200.00 \text{ lbs}$$

Uniform Load = 50 plf

$$R_{PTI.50} := 1.0 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$R_{PTI.50} = 195.83 \text{ lbs}$$

For Wind Pressure

$$R_{PTI.wind} := 1.0 \cdot \left(\frac{q_{wind}}{144} \right) \cdot H_{post} \cdot L$$

$$R_{PTI.wind} = 84.86 \text{ lbs}$$

$$R_{PTI} := \max(R_{PTI.200}, R_{PTI.50}, R_{PTI.wind})$$

$$R_{PTI} = 200.00 \text{ lbs}$$

Maximum Moment:

$$M_{PTI} := R_{PTI} \cdot H_{post}$$

$$M_{PTI} = 5200.00 \text{ in - lb}$$

Maximum Shear:

$$V_{PTI} := R_{PTI}$$

$$V_{PTI} = 200.00 \quad \text{lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PTL.xx} := \frac{M_{PTI}}{F_{b_{PT.I}}}$$

$$S_{PTL.xx} = 0.25 \quad \text{in}^3$$

Shear Design: Area Required:

$$A_{PTL.xx} := \frac{1.5 \cdot V_{PTI}}{F_{v_{PT.I}}}$$

$$A_{PTL.xx} = 0.02 \quad \text{in}^2$$

Post Intermediate Section Provided:

$$BENDING_{PT.I} := \text{if}(S_{PTL.xx} \geq S_{X_{PT.I}}, "N.G", "OK")$$

$$BENDING_{PT.I} = "OK"$$

$$SHEAR_{PT.I} := \text{if}(A_{PTL.xx} \geq A_{PT.I}, "N.G", "OK")$$

$$SHEAR_{PT.I} = "OK"$$

Post Anchor Along X-X Axis Design:

Maximum Reactions:

Concentrated Load = 200 lbs.

$$R_{PT.200} := P_{200}$$

$$R_{PT.200} = 200.00 \quad \text{lbs}$$

Uniform Load = 50 plf

$$R_{PT.50} := 1.0 \cdot \left(\frac{q_{50}}{12} \right) \cdot L$$

$$R_{PT.50} = 195.83 \quad \text{lbs}$$

For Wind Pressure

$$R_{PT.wind} := 1.0 \cdot \left(\frac{q_{wind}}{144} \right) \cdot H_{post} \cdot L$$

$$R_{PT.wind} = 84.86 \quad \text{lbs}$$

$$R_{PT.xx} := \max(R_{PT.200}, R_{PT.50}, R_{PT.wind})$$

$$R_{PT.xx} = 200.00 \quad \text{lbs}$$

Maximum Moment:

$$M_{PT.xx} := R_{PT.xx} \cdot H_{post}$$

$$M_{PT.xx} = 5200.00 \quad \text{in - lb}$$

Maximum Shear:

$$V_{PT.xx} := R_{PT.xx}$$

$$V_{PT.xx} = 200.00 \quad \text{lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PT.xx} := \frac{M_{PT.xx}}{Fb_{PT}}$$

$$S_{PT.xx} = 0.25 \text{ in}^3$$

Shear Design: Area Required:

$$A_{PT.xx} := \frac{1.5 \cdot V_{PT.xx}}{Fv_{PT}}$$

$$A_{PT.xx} = 0.02 \text{ in}^2$$

Post Anchor Section Provided:

$$BENDING_{PT.xx} := \text{if}(S_{PT.xx} \geq S_{xPT}, \text{"N.G"}, \text{"OK"})$$

$$BENDING_{PT.xx} = \text{"OK"}$$

$$SHEAR_{PT.xx} := \text{if}(A_{PT.xx} \geq A_{PT}, \text{"N.G"}, \text{"OK"})$$

$$SHEAR_{PT.xx} = \text{"OK"}$$

Post Anchor Along Y-Y Axis Design (Cable Tension):

Maximum Moment:

$$M_{PT.yy} := \frac{T_{\text{cable}} \cdot \text{floor} \left(\frac{H_{\text{post}}}{s_{\text{cable}}} \right) \cdot H_{\text{post}}}{8}$$

$$M_{PT.yy} = 7935.76 \text{ in} - \text{lb}$$

Maximum Shear:

$$V_{\text{post}_{\text{max},yy}} := \frac{T_{\text{cable}} \cdot \text{floor} \left(\frac{H_{\text{post}}}{s_{\text{cable}}} \right)}{2}$$

$$V_{\text{post}_{\text{max},yy}} = 1220.89 \text{ lbs.}$$

Section Required:

Bending Design: Section Modulus Required:

$$S_{PT.yy} := \frac{M_{PT.yy}}{Fb_{PT}}$$

$$S_{PT.yy} = 0.37 \text{ in}^3$$

Shear Design (Area Required)

$$A_{PT.yy} := \frac{1.5 \cdot V_{\text{post}_{\text{max},yy}}}{Fv_{PT}}$$

$$A_{PT.yy} = 0.14 \text{ in}^2$$

Post Anchor Section Provided:

$$BENDING_{PT.yy} := \text{if}(S_{PT.yy} \geq S_{yPT}, \text{"N.G"}, \text{"OK"})$$

$$BENDING_{PT.yy} = \text{"OK"}$$

$$SHEAR_{PT.yy} := \text{if}(A_{PT.yy} \geq A_{PT}, \text{"N.G"}, \text{"OK"})$$

$$SHEAR_{PT.yy} = \text{"OK"}$$

Post Anchor Combined Stress (Bending at Hpost/2)

$$fb_{PT.xx.0.5H} := \frac{M_{PT.xx}}{2S_{xPT}}$$

$$fb_{PT.xx.0.5H} = 2854.01 \text{ psi}$$

$$fb_{PT.yy} := \frac{M_{PT.yy}}{S_{yPT}}$$

$$fb_{PT.yy} = 8711.05 \text{ psi}$$


$$IE_{PT} := \frac{fb_{PT.xx.0.5H}}{Fb_{PT}} + \frac{fb_{PT.yy}}{Fb_{PT}}$$

$$IE_{PT} = 0.55$$

$$COMBINED_{PT} := \begin{cases} \text{"N.G."} \\ \text{"OK"} & \text{if } 1 \geq IE_{PT} \end{cases}$$

$$COMBINED_{PT} = \text{"OK"}$$

Post Anchorage to Concrete:



Post Data:

$$B_{post} := 2$$

Post Width (in)

$$D_{post} := 2$$

Post Depth (in)

$$h_{ef} := 4.5$$

Post Embedment (in)

$$C_{a1} := 6$$

Minimum Edge Distance (in)

Grout Size Data:

$$B_{\text{grout}} := 4 \quad \text{Equivalent Grout Width (in)}$$

$$D_{\text{grout}} := 4 \quad \text{Equivalent Grout Depth (in)}$$

$$f_{c_{\text{grout}}} := 10000.00 \quad \text{Grout Strength (psi)}$$

Concrete Slab Data:

$$f_{c_{\text{concrete}}} := 4000 \quad \text{Concrete Strength (psi)}$$

$$d_o := 4 \quad \text{Hold diameter (Grout Diameter) (in)}$$

$$h_a := 12 \quad \text{Concrete Slab Deep (in)}$$

Equivalent Maximum Horizontal Load at Top Railing Height (Pd)

$$P_d := R_{PT.xx} \quad P_d = 200.00 \quad \text{lbs}$$

Arm Effect:

$$a := \frac{2 \cdot h_{ef}^2 + 3 \cdot H_{post} \cdot h_{ef}}{3 \cdot h_{ef} + 6 \cdot H_{post}} \quad a = 2.31 \quad \text{in}$$

$$P_2 := \frac{P_d \cdot a^2}{h_{ef} \cdot (2 \cdot a - h_{ef})} \quad P_2 = 1984.66 \quad \text{lbs}$$

$$P_1 := P_2 - P_d \quad P_1 = 1784.66 \quad \text{lbs}$$

$$M_{\text{external}} := P_d \cdot (H_{post} + a) \quad M_{\text{external}} = 5661.95 \quad \text{lbs} - \text{in}$$

$$M_{\text{internal}} := P_2 \cdot \frac{2}{3} \cdot a + P_1 \cdot \frac{2}{3} \cdot (h_{ef} - a) \quad M_{\text{internal}} = 5661.95 \quad \text{lbs} - \text{in}$$

$$V_u := 1.6 \cdot (\max(P_1, P_2)) \quad V_u = 3175.46 \quad \text{lbs}$$

Stress Analysis Between Post and Grout:

$$f_{2,\text{grout}} := 1.6 \cdot \frac{2 \cdot P_2}{a \cdot B_{\text{post}}}$$

$$f_{2,\text{grout}} = 1374.81 \quad \text{psi}$$

$$f_{1,\text{grout}} := 1.6 \cdot \frac{2 \cdot P_1}{(h_{\text{ef}} - a) \cdot B_{\text{post}}}$$

$$f_{1,\text{grout}} = 1303.70 \quad \text{psi}$$

Bearing Stress for Grout :

$$F_{p\text{grout}} := [0.65 \cdot (0.85 f_{c\text{grout}})] \cdot 1.5$$

$$F_{p\text{grout}} = 8287.50 \quad \text{psi}$$

$$\text{Stress}_{\text{grout}} := \begin{cases} \text{"N.G."} \\ \text{"O.K."} & \text{if } \max(f_{1,\text{grout}}, f_{2,\text{grout}}) \leq F_{p\text{grout}} \end{cases}$$

$$\text{Stress}_{\text{grout}} = \text{"O.K."}$$

Stress Analysis Between Grout and Concrete:

$$f_{2,\text{concrete}} := 1.6 \cdot \frac{2 \cdot P_2}{a \cdot B_{\text{grout}}}$$

$$f_{2,\text{concrete}} = 687.41 \quad \text{psi}$$

$$f_{1,\text{concrete}} := 1.6 \cdot \frac{2 \cdot P_1}{(h_{\text{ef}} - a) \cdot B_{\text{grout}}}$$

$$f_{1,\text{concrete}} = 651.85 \quad \text{psi}$$

Bearing Stress for Concrete :

$$F_{p\text{concrete}} := [0.65 \cdot (0.85 \cdot f_{c\text{concrete}})] \cdot 1.5$$

$$F_{p\text{concrete}} = 3315.00 \quad \text{psi}$$

$$\text{Stress}_{\text{concrete}} := \begin{cases} \text{"N.G."} \\ \text{"O.K."} & \text{if } \max(f_{1,\text{concrete}}, f_{2,\text{concrete}}) \leq F_{p\text{concrete}} \end{cases}$$

$$\text{Stress}_{\text{concrete}} = \text{"O.K."}$$

Shear Analysis-Concrete Breakout Strength:

$$A_{V\text{co}} := 4.5 \cdot C_{a1}^2$$

$$A_{V\text{co}} = 162 \quad \text{in}^2$$

$$A_{Vc} := \begin{cases} 2 \cdot (1.5 \cdot C_{a1}) \cdot h_a & \text{if } h_a < 1.5 \cdot C_{a1} \\ 2 \cdot (1.5 \cdot C_{a1}) \cdot (1.5 \cdot C_{a1}) & \text{if } h_a \geq 1.5 \cdot C_{a1} \end{cases}$$

$$A_{Vc} = 162.00 \quad \text{in}^2$$

$$\psi_{ed.V} := 1.00 \quad \text{Modification factor for edge effect}$$

$$\psi_{c.V} := 1 \quad \text{Modification Factor in No cracked concrete at service loads}$$

$\psi_{c.V}=1.4$
 Modification Factor in cracked concrete with
 $\psi_{c.V}=1$ w/ No supplementary reinforcement.
 $\psi_{c.V}=1.2$ w/ Supplementary reinforcement of a No 4 Bar between the anchor and the edge.
 $\psi_{c.V}=1.4$ w/ Supplementary reinforcement of No 4 Bar and stirrups spaced at not more than 4 in

$$l_e := \text{if}(h_{ef} > 8 \cdot d_o, 8 \cdot d_o, h_{ef}) \quad l_e = 4.50 \text{ in}$$

$$V_b := 7 \cdot \left[\left(\frac{l_e}{d_o} \right)^{0.2} \sqrt{d_o} \cdot \sqrt{f_{c_{concrete}}} \cdot C_{a1}^{1.5} \right] \quad V_b = 13323.41 \text{ lbs.}$$

$$V_{cb} := \frac{A_{Vc}}{A_{Vco}} \cdot \psi_{ed.V} \cdot \psi_{c.V} \cdot V_b \quad V_{cb} = 13323.41 \text{ lbs.}$$

$$\phi := 0.7 \quad \text{Conditions}$$

$\phi=0.75$ w/ Supplementary reinforcement are crossing concrete failure prism.
 $\phi=0.70$ w/ No supplementary reinforcement are crossing concrete failure prism.

$$\phi \cdot V_{cb} = 9326.39 \text{ lbs}$$

$$\text{BREAKOUT}_{\text{shear}} := \text{if}(V_u > \phi \cdot V_{cb}, \text{"N.G."}, \text{"OK"}) \quad \text{BREAKOUT}_{\text{shear}} = \text{"OK"}$$

Shear Analysis-Concrete Burst-Out Strength:

$$C_{a1c} := \begin{cases} C_{a1} \\ \text{"N/A"} & \text{if } h_a < C_{a1} \end{cases} \quad C_{a1c} = 6.00 \text{ in}$$

Total Cone Area for Failure Plane

$$A_{\text{cone.total}} := \sqrt{2} \cdot C_{a1c} \cdot \pi \cdot \left(C_{a1c} - \frac{D_{\text{grout}}}{2} + \frac{B_{\text{grout}}}{2} \right) \quad A_{\text{cone.total}} = 159.94 \text{ in}^2$$

Cone Area for Failure Plane at Post

$$A_{\text{cone.post}} := \sqrt{2} \cdot \left(\frac{B_{\text{grout}}}{2} \right)^2 \cdot \pi \quad A_{\text{cone.post}} = 17.77 \text{ in}^2$$

Final Cone Area for Failure Plane

$$A_{\text{cone.final}} := \frac{A_{\text{cone.total}} - A_{\text{cone.post}}}{2}$$

$$A_{\text{cone.final}} = 71.09 \text{ in}^2$$

Final Area for Failure Plane

$$V_{\text{cone.cb}} := 4 \cdot \sqrt{f_{\text{concrete}}} \cdot A_{\text{cone.final}}$$

$$V_{\text{cone.cb}} = 17983.53 \text{ lbs}$$

$$\phi_{\text{B.O}} := 0.75$$

Conditions
 $\phi = 0.75$ for Any Condition

$$\phi_{\text{B.O}} \cdot V_{\text{cone.cb}} = 13487.64 \text{ lbs}$$

$$\text{BURSTOUT}_{\text{shear}} := \text{if}(V_u > \phi_{\text{B.O}} \cdot V_{\text{cone.cb}}, \text{"N.G."}, \text{"OK"})$$

$$\text{BURSTOUT}_{\text{shear}} = \text{"OK"}$$

Weld Design For POST-TOP

MATERIALS:

Welding: Aluminum Filler Alloy 5183

Weld and Section Data:

$F_v := 14.4$ Allowable Stress for Welding (ksi)

$b := 2$ Width of POST (in)

$d := 2$ Depth of POST (in)

Load Data:

$M_{\text{weld}} := 0$ Moment (Kips-ft)

$V_{\text{weld}} := 1.221$ Shear (Kips)

$P_{\text{weld}} := 0.00$ Tension or Compression (Kips)

$T_{\text{weld}} := 0.00$ Torsional Moment (kips-ft)

Check Weld Section :

$$t_e := \begin{cases} x \leftarrow 0.00001 \\ \text{while } \sqrt{\left[\frac{P_{\text{weld}}}{2(b+d) \cdot x} + \frac{M_{\text{weld}} \cdot 12}{\left(b \cdot d + \frac{d^2}{3}\right) \cdot x} \right]^2 + \left[\frac{1.5V_{\text{weld}}}{2(b+d) \cdot x} + \frac{T_{\text{weld}} \cdot 12 \cdot \sqrt{\left(\frac{b}{2}\right)^2 + \left(\frac{d}{2}\right)^2}}{\frac{(b+d)^3}{6} \cdot x} \right]^2} \geq F_v \\ x \leftarrow x + 0.01 \end{cases}$$

$$t_e = 0.02 \text{ in}$$

$$S_{\text{weld}} := \left(b \cdot d + \frac{d^2}{3} \right) \cdot t_e$$

$$S_{\text{weld}} = 0.11 \text{ in}^3$$

$$A_{\text{weld}} := 2 \cdot (d + b) \cdot t_e$$

$$A_{\text{weld}} = 0.16 \text{ in}^2$$

$$J_{\text{weld}} := \frac{(b+d)^3}{6} \cdot t_e$$

$$J_{\text{weld}} = 0.21 \text{ in}^3$$

Check Bending Stress :

$$f_b := \frac{M_{\text{weld}} \cdot (12)}{S_{\text{weld}}}$$

$$f_b = 0.00 \quad \text{ksi}$$

Check Shear Stress :

$$f_v := \frac{1.5V_{\text{weld}}}{A_{\text{weld}}} + \frac{T_{\text{weld}} \cdot 12 \cdot \sqrt{\left(\frac{b}{2}\right)^2 + \left(\frac{d}{2}\right)^2}}{J_{\text{weld}}}$$

$$f_v = 11.44 \quad \text{ksi}$$

Check Tension Stress :

$$f_a := \frac{P_{\text{weld}}}{A_{\text{weld}}}$$

$$f_a = 0.00 \quad \text{Ksi}$$

Check Combined Stress :

$$f_{\text{weld}} := \sqrt{(f_b + f_a)^2 + f_v^2}$$

$$f_{\text{weld}} = 11.44 \quad \text{ksi}$$

$$\text{STRESS} := \begin{cases} \text{"N.G."} \\ \text{"OK"} & \text{if } F_v \geq f_{\text{weld}} \end{cases}$$

$$\text{STRESS} = \text{"OK"}$$

$$W_{\text{weld}} := \begin{cases} \text{"1/8"} & \text{if } \frac{t_e}{0.707} \leq 0.125 \\ \text{"3/16"} & \text{if } 0.125 < \frac{t_e}{0.707} \leq 0.1875 \\ \text{"1/4"} & \text{if } 0.25 < \frac{t_e}{0.707} \leq 0.25 \\ \text{"1/2"} & \text{if } 0.375 < \frac{t_e}{0.707} \leq 0.50 \\ \text{"5/8"} & \text{if } 0.50 < \frac{t_e}{0.707} \leq 0.625 \\ \text{"3/4"} & \text{if } 0.625 < \frac{t_e}{0.707} \leq 0.750 \\ \text{"1"} & \text{if } 0.75 < \frac{t_e}{0.707} \leq 1.00 \end{cases}$$

$$W_{\text{weld}} = \text{"1/8"}$$




Table 24
RECTANGULAR TUBES

Designation	Width <i>b</i> in.	Depth <i>d</i> in.	Thickness <i>t</i> in.	Weight lb/ft	Area <i>A</i> in ²	Axis x-x			Axis y-y		
						<i>I_x</i> in ⁴	<i>S_x</i> in ³	<i>r_x</i> in.	<i>I_y</i> in ⁴	<i>S_y</i> in ³	<i>r_y</i> in.
RT 1 x 1 1/2 x 1/8	1.000	1.500	0.125	0.662	0.563	0.159	0.212	0.532	0.0811	0.162	0.380
RT 1 x 2 x 1/8	1.000	2.000	0.125	0.809	0.688	0.332	0.332	0.695	0.105	0.210	0.391
RT 1 x 2 1/2 x 1/8	1.000	2.500	0.125	0.956	0.813	0.590	0.472	0.852	0.129	0.258	0.399
RT 1 x 3 x 1/8	1.000	3.000	0.125	1.10	0.938	0.950	0.633	1.01	0.153	0.307	0.404
RT 1 x 4 x 1/8	1.000	4.000	0.125	1.40	1.19	2.04	1.02	1.31	0.201	0.403	0.412
RT 1 1/4 x 2 x 1/8	1.250	2.000	0.125	0.882	0.750	0.387	0.387	0.718	0.180	0.288	0.489
RT 1 1/4 x 2 1/2 x 1/8	1.250	2.500	0.125	1.03	0.875	0.678	0.543	0.881	0.219	0.351	0.501
RT 1 1/4 x 3 x 1/8	1.250	3.000	0.125	1.18	1.00	1.08	0.720	1.04	0.259	0.415	0.509
RT 1 1/2 x 1 3/4 x 1/8	1.500	1.750	0.125	0.882	0.750	0.318	0.364	0.652	0.248	0.331	0.575
RT 1 1/2 x 2 x 1/8	1.500	2.000	0.125	0.956	0.813	0.442	0.442	0.737	0.278	0.370	0.585
RT 1 1/2 x 2 x 1/4	1.500	2.000	0.250	1.76	1.50	0.719	0.719	0.692	0.438	0.563	0.540
RT 1 1/2 x 2 1/2 x 1/8	1.500	2.500	0.125	1.10	0.938	0.767	0.613	0.904	0.337	0.449	0.599
RT 1 1/2 x 3 x 1/8	1.500	3.000	0.125	1.25	1.06	1.21	0.806	1.07	0.396	0.528	0.611
RT 1 1/2 x 3 x 3/16	1.500	3.000	0.188	1.82	1.55	1.68	1.12	1.04	0.533	0.711	0.586
RT 1 1/2 x 4 x 1/8	1.500	4.000	0.125	1.54	1.31	2.51	1.25	1.38	0.515	0.686	0.626
RT 1 1/2 x 6 x 1/8	1.500	6.000	0.125	2.13	1.81	7.20	2.40	1.99	0.752	1.00	0.644
RT 1 3/4 x 2 x 1/8	1.750	2.000	0.125	1.03	0.875	0.497	0.497	0.753	0.401	0.458	0.677
RT 1 3/4 x 2 1/4 x 1/8	1.750	2.250	0.125	1.10	0.938	0.661	0.588	0.840	0.442	0.506	0.687
RT 1 3/4 x 2 1/2 x 1/8	1.750	2.500	0.125	1.18	1.00	0.855	0.684	0.925	0.484	0.553	0.696
RT 1 3/4 x 2 3/4 x 1/8	1.750	2.750	0.125	1.25	1.06	1.08	0.785	1.01	0.525	0.600	0.703
RT 1 3/4 x 3 x 1/8	1.750	3.000	0.125	1.32	1.13	1.34	0.892	1.09	0.566	0.647	0.710
RT 1 3/4 x 3 1/2 x 1/8	1.750	3.500	0.125	1.47	1.25	1.96	1.12	1.25	0.649	0.742	0.721
RT 1 3/4 x 4 x 1/8	1.750	4.000	0.125	1.62	1.38	2.74	1.37	1.41	0.732	0.836	0.730
RT 1 3/4 x 4 1/2 x 1/8	1.750	4.500	0.125	1.76	1.50	3.69	1.64	1.57	0.814	0.931	0.737
RT 1 3/4 x 5 x 1/8	1.750	5.000	0.125	1.91	1.63	4.83	1.93	1.72	0.897	1.03	0.743
RT 1 3/4 x 5 x 3/16	1.750	5.000	0.188	2.82	2.40	6.91	2.76	1.70	1.23	1.41	0.717
RT 1 3/4 x 6 x 1/8	1.750	6.000	0.125	2.21	1.88	7.74	2.58	2.03	1.06	1.21	0.753




Table 23
SQUARE TUBES

Designation	Depth width d in.	Thickness t in.	Weight lb/ft	Area A in ²	Axis x-x, y-y			J in ⁴
					I_x, I_y in ⁴	S_x, S_y in ³	r_x, r_y in.	
RT 1 × 1 × .065	1.000	0.065	0.286	0.243	0.0356	0.0712	0.383	0.0531
RT 1 × 1 × .095	1.000	0.095	0.404	0.344	0.0475	0.0949	0.371	0.0704
RT 1 × 1 × .125	1.000	0.125	0.515	0.438	0.0570	0.114	0.361	0.0837
RT 1.25 × 1.25 × .065	1.250	0.065	0.362	0.308	0.0723	0.116	0.485	0.108
RT 1.25 × 1.25 × .095	1.250	0.095	0.516	0.439	0.0982	0.157	0.473	0.146
RT 1.25 × 1.25 × .125	1.250	0.125	0.662	0.563	0.120	0.192	0.462	0.178
RT 1.375 × 1.375 × .125	1.375	0.125	0.735	0.625	0.164	0.239	0.513	0.244
RT 1.5 × 1.5 × .065	1.500	0.065	0.439	0.373	0.128	0.171	0.586	0.192
RT 1.5 × 1.5 × .078	1.500	0.078	0.522	0.444	0.150	0.200	0.581	0.224
RT 1.5 × 1.5 × .095	1.500	0.095	0.628	0.534	0.176	0.235	0.575	0.263
RT 1.5 × 1.5 × .125	1.500	0.125	0.809	0.688	0.218	0.291	0.564	0.325
RT 1.5 × 1.5 × .250	1.500	0.250	1.47	1.25	0.339	0.451	0.520	0.488
RT 1.75 × 1.75 × .125	1.750	0.125	0.956	0.813	0.360	0.411	0.665	0.536
RT 2 × 2 × .095	2.000	0.095	0.851	0.724	0.439	0.439	0.779	0.657
RT 2 × 2 × .125	2.000	0.125	1.10	0.938	0.552	0.552	0.767	0.824
RT 2 × 2 × .156	2.000	0.156	1.35	1.15	0.657	0.657	0.755	0.978
RT 2 × 2 × .188	2.000	0.188	1.60	1.36	0.754	0.754	0.744	1.12
RT 2 × 2 × .250	2.000	0.250	2.06	1.75	0.911	0.911	0.722	1.34
RT 2.25 × 2.25 × .125	2.250	0.125	1.25	1.06	0.802	0.713	0.869	1.20
RT 2.5 × 2.5 × .125	2.500	0.125	1.40	1.19	1.12	0.896	0.971	1.67
RT 2.5 × 2.5 × .188	2.500	0.188	2.04	1.74	1.56	1.25	0.947	2.32
RT 2.5 × 2.5 × .250	2.500	0.250	2.65	2.25	1.92	1.54	0.924	2.85
RT 2.75 × 2.75 × .125	2.750	0.125	1.54	1.31	1.51	1.10	1.07	2.26
RT 2.75 × 2.75 × .188	2.750	0.188	2.27	1.93	2.12	1.54	1.05	3.16
RT 3 × 3 × .095	3.000	0.095	1.30	1.10	1.55	1.04	1.19	2.33
RT 3 × 3 × .125	3.000	0.125	1.69	1.44	1.98	1.32	1.17	2.97
RT 3 × 3 × .188	3.000	0.188	2.49	2.11	2.80	1.87	1.15	4.18
RT 3 × 3 × .250	3.000	0.250	3.23	2.75	3.49	2.33	1.13	5.20
RT 3 × 3 × .375	3.000	0.375	4.63	3.94	4.61	3.08	1.08	6.78
RT 3.5 × 3.5 × .125	3.500	0.125	1.98	1.69	3.21	1.83	1.38	4.81
RT 3.5 × 3.5 × .250	3.500	0.250	3.82	3.25	5.76	3.29	1.33	8.58
RT 3.5 × 3.5 × .375	3.500	0.375	5.51	4.69	7.74	4.42	1.28	11.4
RT 4 × 4 × .125	4.000	0.125	2.28	1.94	4.85	2.43	1.58	7.27
RT 4 × 4 × .188	4.000	0.188	3.37	2.87	6.96	3.48	1.56	10.4
RT 4 × 4 × .250	4.000	0.250	4.41	3.75	8.83	4.41	1.53	13.2
RT 4 × 4 × .375	4.000	0.375	6.39	5.44	12.0	6.02	1.49	17.9
RT 4 × 4 × .500	4.000	0.500	8.23	7.00	14.6	7.29	1.44	21.4