

Village of Pinecrest

Gulliver Preparatory School, Inc. - Temporary Modular Classrooms

Narrative Response to Comments for BL2026-0415

**Building:**

**Comment:** 4/8/2026 10:20:18 AM

- DERM APPROVAL REQUIRED
- HEALTH DEPARTMENT
- WASD APPROVAL REQUIRED
- IMPACT FEE REVIEW
- MIAMI-DADE FIRE APPROVAL REQUIRED

1. VOID
2. PROVIDE LOCATION OF REFERENCED MODULAR PIER FOUNDATION PLAN.
3. SPECIAL INSPECTOR REQUIRED FOR DECK ASSEMBLY/AUGERS..

**Response:** See foundation plan provided by modular vendor. Special inspector forms provided. County approval achieved.

**Structural:**

**Comment:** 4/8/2026 9:26:13 AM

Provide foundation plan for modular buildings, include soil statement on plans.

**Response:** See foundation plan provided by modular vendor. Soils statement included on plan under foundation notes #7.

Thank you.