PERMIT Nº BL2026-0875 / WINDOWS

PLANS PROCESSOR REVIEW / FINAL PERMIT CLERK

INCOMPLETE

BUILDING REVIEW / PAUL BUCKLER

INCOMPLETE

7/14/2026 8:21:23 AM - INCOMPLETE

1. A Village of Pinecrest “window and door supplement form” completely filled is required for shop drawing approval. A schedule showing similar information may be used instead. Include calculated negative & positive pressures for openings as well as capacity negative and positive pressures.

   RESPONSE.- Please find the requested form attached, completed with the required information.

2. Highlight all pertinent information applicable to the installation on N.O.A. documents. Mark glass type, size and load capacity on charts.

   RESPONSE.- Please find the requested form attached, completed with the required information.

PERMIT CLERK REVIEW / PERMIT CLERK

7/6/2026 - INCOMPLETE

7/6/2026 9:26:11 AM PLANS SUBMITTED FOR REVIEW MUST BE DIGITALLY SIGNED AND SEALED

RESPONSE.- Please find the requested form attached, completed with the required information