



AM American Consulting, Inc.
14331 SW 120th Street, Suite 213,
Miami, FL 33186, Ph: (786) 219 9490
www.amamericanconsulting.com

October 05, 2026

To: City Comments

Re: 10635 SW 65th Avenue, Miami, FL 33196
City Comments, Exterior Windows & Doors Shop Drawings

We are submitting a response to the comments generated during your review of the project.

Original Comment:

1. Per N.O.A FL41358.1 for “ES PIVOT DOOR” Opening #100. General notes on page 1, this door is not approved for use in openings required to meet water infiltration requirements. It can be used in locations that conform with the overhang ratio requirements on the F.B.C. Building Section 2411.3.2 Exemption 2. Please provide documentation in the form of a section showing dimensions from door threshold to bottom of overhang and from door to outer edge of overhang.

Response:


The Shop Drawings have been updated, and a note regarding the water resistance requirement has been added to the drawings.

If you have any additional questions or comments, please give us a call at (786) 219-9490/or (786) 200-5030. You may also reach us by e-mail: daniel@amamericanconsulting.com

Thanks,

Best Regards,

This item has been digitally signed and sealed by Daniel Gonzalez, PE 74271, on the date adjacent to the seal. Signature must be verified on any electronic copies.



Digitally signed
by Daniel
Gonzalez
Date:
2026.10.05
17:56:39-04'00'

Daniel Gonzalez, PE
Lic. No. 74271
CA No. 31388