



VILLAGE OF PINECREST
Building & Planning Department

12645 Pinecrest Parkway,
Pinecrest, Florida 33156

Allen
Slamic

Digitally signed by Allen Slamic
DN: cn=Allen Slamic,
o=AlexAllen Studio Architects
PLLC,
email=allen@alexallenstudio.co
m, c=US
Date: 2026.09.28 14:18:34
-04'00'
Adobe Acrobat version:
2026.002.21901

PERMIT # BL-2022-0447

JOB ADDRESS 12020 SW 77th Avenue, Pinecrest, FL 33156

WINDOW & DOOR PERMIT SUPPLEMENT FORM

MARK	MFR'S GLASS TYPE	UNIT DIMENSIONS	UNIT TYPE	PRODUCT APPROVAL/ N.O.A.	CALCULATED WIND PRESSURE (BY DESIGN PROFESSIONAL)		PRESSURE CAPACITY (FROM NOA)	
					(-)	(+)	(-)	(+)
E1	A	24" X 36"	CSMT	FL20-1234	57.0	42.6	60.0	60.0
E2	N/A	4" X 2" X 96"	MULLION	20-1234.5	—	—	—	—
1.08	5/16"	108"H X 216"W	GARAGE DOOR	FL #47490.2	50.43	39.15	55	45
	LAMINATED							
1.09	5/16"	108"H X 114"W	GARAGE DOOR	FL #47490.2	42.63	39.15	55	45
	LAMINATED							
1.11	N/A	134"H X 60"W	PIVOT DOOR	FL #41748	43.44	39.95	65	65

- 1) ATTACH FLOOR PLAN INDICATING ALL EXTERIOR OPENINGS, MARK AS "N/A" IF NOT IN PERMIT SCOPE.
- 2) SUBMIT THIS FORM WITH TWO SETS OF NOTICE OF ACCEPTANCE OR PRODUCT APPROVAL FOR EACH TYPE.

(Revised 3/14/2022)