


VILLAGE OF PINECREST

SEC. 15 - 55 - 40



POSTED SPEED



"VILLAGE OF PINECREST REQUIREMENTS"

DIRECTIONAL BORE ONLY
NO PAVEMENT CUTS
START DATE, \ COMPLETION DATE,
RESTORATION OF CONSTRUCTION AREAS
AS IT WAS OR BETTER



SYMBOL FOR APPROVED TREE PROTECTION FENCE

" ALL TREES TO REMAIN "

START OF CONSTRUCTION: _____

COMPLETION OF CONSTRUCTION: _____

NOTE:
APPROVED DENSITY TEST ORIGINAL MUST
BE SUBMITTED TO VILLAGE OF PINECREST
PUBLIC WORKS DEPT. PRIOR TO INSTALLING
ANY ASPHALT.

5/5/2026 REVISED AND UPDATED. DAC

GENERAL NOTES

1. LANE CLOSURES PER F.D.O.T. STD. PLAN INDEX # 102-602
2. PAVEMENT RESTORATION PER M.D.C.P.W.M. R-21.1.
3. SIDEWALK RESTORATION PER M.D.C.P.W.M. R-13.1.
4. MAINTAIN MIN. 30" COVER ON ALL SERVICE LINES.
5. DO NOT SET METER(S) AT THIS TIME.
6. 48 HOURS BEFORE DIGGING CALL SUNSHINE STATE ONE
CALL AT **1-800-432-4770** TICKET #. 086601792

- | | | |
|--|---|--|
| ☐ F.P.L. | ☒ M.D. PW & TRAFFIC | ☐ MDC IT DEPT |
| ☒ MCI | ☒ A.T. & T. DIST. | ☒ MD-WATER |
| ☒ F.P.L.-TRANSM. | ☒ CITY GAS | ☒ MD-SEWER |

DRAWN: DAC DATE: 04/13/2026 REV: PV

**NEW WATER SERVICE AND
EXISTING SERVICE
RETIREMENT AT
12020 SW 77 AVE**

90007-SIRP-3627

MIAMI - DADE WATER AND SEWER DEPARTMENT