

ANSWER SHEET: EXPEDITE TEMP FENCE FOR CONSTRUCTION

PZ2024-0420 6545 SW 131 ST

Type: **PUBLIC WORKS – CONSTRUCTION ENTRANCE**

Reviewer: **DAVID MENDEZ**

Notes: 9/17/2024

The PDF with the required construction entrance detail has been voided. The construction entrance detail must be part of the plans and must be installed per the detail. The survey sheet references "gravel". The detail calls for ballast rock.

**ATTACHED CONSTRUCTION ENTRANCE DETAIL.
BALLAST ROCK CORRECTED**