



ANSWER TO COMMENTS

12/10/2025

Miami, FL

**Village of Pinecrest
Building Official**

Project: 10840 SW 67 St
Process #: #PZ2025-0192

In response to your comments on the above-mentioned project, please find the following:

DISCIPLINE

PUBLIC WORKS

Review the limits of the temporary construction entrance from the detail. The diversion ridge is INSIDE the property.

The ballast rock must extend from the BACK of sidewalk to 30'; INSIDE the property.

Response: Please refer to D-101.

Matias Daroch, AIA
Architect AR100480