THIS IS AN ADDITIONAL OPTION THAT THE CLIENT WANTS TO PROVIDE FOR THE FUTURE OWNER TO INSTAL THEIR OWN EQUIPMENTAS THIS IS A SPEC HOME. NO NEED TO INSTALL AT TIME OF TCO/CO BECAUSE WE COMPLY BY PROVIDING AUXILLIARY POWER BY MEANS OF OPTION "B"

4. Auxiliary Power Supply: New residential and commercial structures and substantial improvements to residential structures exceeding 50 percent of the market value of the existing structure shall include one of the following improvements necessary to provide auxiliary power during electrical power outages:

a) permanent installation of a stand by generator (separate permit) or

b) Installation of a power inlet and either a separate electric or interlock allowing for connection to a portable generator or

c) Solar panel and battery pack necessary to provide auxiliary power

Please note that this is separate from Solar Ready requirement and must be in place prior to receiving TCO or CO.

WE ARE PROVIDING ELECTRICAL AUXILLIARY POWER AS PER OPTION "B" TO SATISFY COMMENT. PLEASE REFER TO REVISED E-202, CUT SHEETS FOR CMLOCK CONNECTION BOX, AND RESPONSE TO COMMENTS BY ELECTRICAL ENGINEER. THESE ELECTRICAL COMPONENTS WILL BE INSTALLED APRIOR RECEIVING TCO OR CO.