


WOOD CONNECTOR SCHEDULE										
ANCHOR LABEL	PRODUCT CODE	MANUFACTURER	ALLOWABLE LOAD (LBS)			FASTENER SCHEDULE			PRODUCT APPROVAL	EXP. DATE
			GRAVITY	UPLIFT	L1	L2	SEAT/BEN/LEADER	STRAP/TROSS/JUST		
1	NWHTA20	NU~WUE	N/A	2849	1575	2175	(8)~10dHx1W" NALS	(18)~10dHx1W" NALS	18~0312/06	05/22/2022
2	NV358~20	NU~WUE	N/A	3367	2942	2758	(8)~10d NALS	(16)~10d NALS	20~0526/05	07/26/2022
3	LSR414	SIMPSON STRONG-TIE	1810	695	N/A	N/A	(20)~14dX24" NALS	(13)~16dX24" NALS	FL 10865	12/31/2022
4	HETA20	SIMPSON STRONG-TIE	N/A	1810	340	770	4" MIN. EMBEDMENT	(8)~16d NALS	FL 11473	12/31/2022
5	HUS28	USP	4745	2990	N/A	N/A	(22)~16d NALS	(8)~16d NALS	FL 17232.6	10/31/2022
6	HTSM20	SIMPSON STRONG-TIE	N/A	1110	120	90	(4)~16dX24" TITEN 2 FASTENER	(10)~10dHx1W" NALS	FL 11473.84	12/31/2022
7	SPECIAL ANCHOR	CUSTOM SEE CALCULATIONS	N/A	10800	6400	7900	REFER TO DET. H/S~6.2		N/A	N/A
8	AB7	NU~WUE	573	573	794	N/A	(4)~100Hx1W" NALS	(4)~100Hx1W" NALS	18~0312/06	5/22/2023
9	SPECIAL ANCHOR	CUSTOM SEE CALCULATIONS	10100	9600	11300	10400	REFER TO DET. H/S~6.2		N/A	N/A
10	HGAM10	SIMPSON STRONG-TIE	N/A	810	875	1105	(4)~NALS1W" TITEN 2 ANCHOR SCS	(4)~NALS1W" SCS	FL 11473.84	12/31/2022

- | | |
|---|--|
|  | DENOTES COLUMN SUPPORT BELOW |
|  | DENOTES BEAM/WALL SUPPORT BELOW |
|  | DENOTES LOAD BEARING CMU WALL |
|   | DENOTES A CONCRETE COLUMN
(REFER TO SCHEDULES) |
|   | DENOTES A STEEL COLUMN
(REFER TO SCHEDULES) |
|  | DENOTES THE DIRECTION OF OUTERMOST
BOTTOM REINFORCEMENT LAYER IN SLAB |
|  | DENOTES A SLAB ELEVATION CHANGE |
|  | DENOTES ROOF OVERFRAMING |
|  | DENOTES WOOD BLOCKED DIAPHRAGM |
|  | DENOTES TONGUE & GROOVE AT
OVERHANGS/CEILING |
|  | DENOTES ROOF CRICKET |
- SLAB REIN. LEGEND**

SIZE

QTY. $\downarrow$

3#5@10

SPACING (INCHES)

$\downarrow$

12" - 0"

LENGTH

T- LOCATION

1: TOP

8: BOTTOM



NEW RESIDENCE FOR:
U.C.M.S. RESIDENCE
9601 S.W. 67TH AVENUE - PINECREST, FLORIDA 33156

date	11-01-2021	revisions	
issued		4 OWNER 03-28-2025	△
drawn	DM, NP	△	△
checked	JJ	2 REV. 01-03-2023	△
project no.	2143/KE-21036	1 BDC 04-07-2022	△