

Narrative: Response to VOP comments for REV2025-0182

Zoning

Type:	ZONING EXPEDITE
Status:	DENIED
Date Submitted:	6/6/2025
Date Due:	6/13/2025
Date Completed:	6/12/2025
Reviewer:	SUBRATA BASU
Remarks:	
Notes:	6/12/2025 2:34:21 PM PLEASE NOTE THAT THE OVERALL NGVD SHOULD BE 47.78 (NOT 47.88 BASED ON THE DIMENSIONS PROVIDED. PLEASE ADJUST THE NUMBERS

Response: Please see the revised Cueto Engineering A-200 drawing with corrected elevation numbers.

Storm Water

Group:	ALL
Type:	STORM EXPEDITE
Status:	DENIED
Date Submitted:	6/6/2025
Date Due:	6/13/2025
Date Completed:	6/16/2025
Reviewer:	MATTHEW BROOKS
Remarks:	
Notes:	6/16/2025 9:48:40 AM 1. Sheet C-1.0: All swales are to have flat bottoms, i.e., no V-shaped swales.

Response: Please see letter dated October 14, 2024. This item came up during the Oct 2024 plan review. Attached is the civil engineer's October 14, 2024 clarification letter in response to this comment. Stormwater review accepted this document and approved the storm water plans for permit.