

August 22, 2025

Revision #3 Comments Responses

Attn: Village of Pinecrest Building Department

Re: Dylan & Jamie Roy Interior Remodeling and Addition Project.
6783 SW 104th St Pinecrest FL, 33156

Comment Responses

1. Provide a detail of drywall dropped soffit above, in front of master bedroom showing height & attachment details.


Response: Refer to revised Sheet A300 for the added detail of the dropped soffit.

2. If any existing electrical outlets are being relocated, indicate on plan.

Response: Refer to revised Sheets E200 and E300 for the relocation of existing switches and outlets.

Regards,

Julio Pulido, AIA
Principal
Novus Archetype, LLC



Digitally signed
by Julio Pulido
Date: 2025.08.22
09:02:01 -04'00'